

DOCUMENT 00902 – ADDENDUM NO.2

PROJECT: INTER-GARRISON ROAD WATER DISTRIBUTION PIPELINE PROJECT

CIP NO.: OW-0206

FROM: District Engineer
Marina Coast Water District
11 Reservation Road
Marina, CA 93933

TO: PROSPECTIVE BIDDERS

This Addendum forms a part of the Bidding Documents and will be incorporated into Contract Documents. Insofar as the Specifications or Drawings or both are inconsistent, this Addendum governs. Acknowledge receipt of the Addendum by inserting its number in Document 00410 – Bid Form.

FAILURE TO DO SO WILL SUBJECT BID TO DISQUALIFICATION.

PART 1 - CHANGES TO PROJECT MANUAL

15. Section 00410

Remove page 00410-4 and replace with new page 00410-4 (attached), to be submitted with bid. This amendment also replaces previously-amended page 00410-4 from Addendum 1.

16. Section 00901 (Addendum 1)

Part 1, Item 12f) *Bid Item 7: Roadway Restoration: This ~~unit~~ lump sum bid price shall include costs for restoring the streets and all other properties, back to initial condition, including a Type II slurry seal covering the full width of the traffic lane in which trenching occurs (approx. 3500 linear feet) and restriping.*

17. Section 00901 (Addendum 1)

Part 3, Item 11) *The 6" specification for the ARVs marked on the profiles (Stations 12+79.52 and 30+77.33) is incorrect. Install ~~manua~~ 1" ARVs per Standard Detail ~~W-8~~ **W-10** on Sheet 4 of the project plans.*

PART 2 - CHANGES TO DRAWINGS

None.

PART 3 – QUESTIONS RECEIVED

Q15: Regarding the required pressure rating for the 18" butterfly valve: MCWD typical specifications call for 150B series which is rated for 150 psi working pressure. It appears the ductile iron callout (PC250 – 250 psi working pressure) as well as all other components for the Inter-Garrison project exceed the capabilities of the 150B/150 psi series valve. Please advise if a 150B (150 psi working pressure) or a 250B (250 psi working pressure) series butterfly valve will be required for this project.

A15: MCWD is requiring a 150B series butterfly valve for this project. Pipe is Class 250 DIP, per plans.

Q16: In Bid Item 6, the 20' segments of capped 18" HDPE storm drain are listed as a lump sum bid, but the bid quantity is listed as 7. Should this be a per-unit bid?

A16: Bid Item 6 is lump sum. The quantity listed in the bid table has been changed (see amended page 00410-4).

Q17: In Bid Item 7, the bid quantity is listed as 2500 SY, but shouldn't this be ~7000 SY if the full traffic lane will require a type 2 slurry seal? Should this be a lump sum item?

A17: Bid Item 7 is lump sum (see amended page 00410-4).

Q18: In Bid Item 7, does the center line need to be restriped, or can slurry be placed to the edge of the center line without restriping?

A18: Slurry and restriping includes centerline striping and reflective markers.

END OF DOCUMENT

ARTICLE 5 – BASIS OF BID

5.01 Bidder will complete the Work in accordance with the Contract Documents for the following price(s):

All specified cash allowances are included in the price(s) set forth above and have been computed in accordance with Paragraph 11.02 of the General Conditions.

Item No.	Description	Unit	Quantity	Unit Price	Total Item Price
1	Mobilization/demobilization	LS	1		
2	Trench safety: Temporary sheeting, shoring and bracing	LS	1		
3	18-Inch Ductile Iron Pipe, incl. all valves, fittings and restraints.	LF	3500		
4	Connection to existing 12” water main east of Schoonover Road, incl. tapping sleeve and all valves/fittings	LS	1		
5	Connection to existing 12” water main west of Sherman Blvd. in East Garrison, incl. all pipe, valves and fittings	LS	1		
6	Install seven (7) 20’ segments of capped 18” HDPE storm drain pipe (for future connection with Eastside Parkway construction), centered beneath water crossing, 1’ clearance minimum	LS	1		
7	Restore streets and all other properties back to initial condition, including a Type II slurry seal covering the full width of the traffic lane in which trenching occurs, and restriping.	LS	1		

Total bid schedule including ADDS/DEDUCTS:

Number: \$ _____

Words: _____

Unit Prices have been computed in accordance with Paragraph 11.03.B of the General Conditions.

Bidder acknowledges that estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Bid items will be based on actual quantities, determined as provided in the Contract Documents.

If the District awards this contract, selection shall be based on the lowest total Bid Price and qualified contractor.