

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 JANUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL	mg/L	mg/L	°F	NTU	Color Units	TON	mg/L
C	6-Jan-2014	Nguyen	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.43	7.90	64	0.077	2	<1	<0.002	498
	6-Jan-2014	Nguyen	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.00	7.68	69	0.067	3	<1	<0.002	569
	6-Jan-2014	Nguyen	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.36	7.65	68	0.065	2	<1	<0.002	567
	6-Jan-2014	Nguyen	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.58	7.82	64	0.120	2	<1	<0.002	488
	6-Jan-2014	Nguyen	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.88	7.81	68	0.069	1	<1	<0.002	530
	6-Jan-2014	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.95	7.66	56	0.082	3	<1		494
	6-Jan-2014	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	0.97	7.68	55	0.068	2	<1		475
	6-Jan-2014	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	0.95	7.71	58	0.072	2	<1		487
	6-Jan-2014	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.60	7.70	60	0.074	2	<1		514
	6-Jan-2014	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.99	7.67	55	0.077	2	<1		470
D	13-Jan-2014	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	1.28	7.52	60	0.120	3	<1	<0.002	736
	13-Jan-2014	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.15	7.41	60	0.097	2	<1	0.002	681
	13-Jan-2014	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.62	7.86	59	0.092	2	<1	<0.002	449
	13-Jan-2014	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.96	7.61	62	0.074	2	<1	0.002	622
	13-Jan-2014	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.97	7.30	65	0.070	2	<1	<0.002	775
	13-Jan-2014	Jackson	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.01	7.60	56	0.105	2	<1		593
	13-Jan-2014	Jackson	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.97	7.49	58	0.108	3	<1		679
	13-Jan-2014	Jackson	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.87	7.51	53	0.086	3	<1		620
	13-Jan-2014	Jackson	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.95	7.60	60	0.083	3	<1		681
	13-Jan-2014	Jackson	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.01	7.58	60	0.670	3	<1		694
A	21-Jan-2014	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.58	7.93	59	0.178	3	<1	0.002	534
	21-Jan-2014	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	0.60	7.95	65	0.150	3	<1	<0.002	574
	21-Jan-2014	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.39	7.94	66	0.434	3	<1	<0.002	583
	21-Jan-2014	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.42	7.96	62	0.073	2	<1	<0.002	558
	21-Jan-2014	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.97	7.95	68	0.091	4	<1	<0.002	548
	21-Jan-2014	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.34	7.90	66	0.142	3	<1		541
	21-Jan-2014	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.77	7.86	58	0.190	3	<1		549
	21-Jan-2014	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.99	7.86	64	0.116	3	<1		583
	21-Jan-2014	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.03	7.94	64	0.051	3	<1		531
	21-Jan-2014	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.10	8.08	66	0.114	4	<1		554
B	27-Jan-2014	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.26	7.53	66	0.067	2	<1	<0.002	589
	27-Jan-2014	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.90	7.32	60	0.075	3	<1	<0.002	696
	27-Jan-2014	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.73	7.29	67	0.073	3	<1	<0.002	838
	27-Jan-2014	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.48	7.53	68	0.061	4	<1	<0.002	732
	27-Jan-2014	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.24	7.30	67	0.065	2	<1	<0.002	759
	27-Jan-2014	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.02	7.52	65	0.089	3	<1		708
	27-Jan-2014	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.98	7.69	65	0.119	3	<1		731
	27-Jan-2014	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.05	7.45	66	0.227	2	<1		728
	27-Jan-2014	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.94	7.59	67	0.097	4	<1		659
	27-Jan-2014	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	0.97	7.53	66	0.079	2	<1		685
AVERAGE								0.86	7.67	63	0.119	3	<1	<0.002	608
MAXIMUM								1.36	8.08	69	0.670	4	<1	0.002	838
MINIMUM								0.24	7.29	53	0.051	1	<1	<0.002	449

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 FEBRUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR**	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°c
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
C	3-Feb-2014	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.92	7.78	64	0.069	2	<1	<0.002	617
	3-Feb-2014	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.90	7.85	68	0.076	2	<1	<0.002	652
	3-Feb-2014	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.93	7.84	67	0.061	3	<1	<0.002	641
	3-Feb-2014	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.88	7.78	62	0.065	2	<1	0.002	605
	3-Feb-2014	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.90	7.83	66	0.071	4	<1	<0.002	636
	3-Feb-2014	Nguyen	C6	DS 314 Ardenes Circle	Routine	Absent	Absent	1.05	7.56	58	0.074	4	<1		619
	3-Feb-2014	Nguyen	C7	DS 325 Buna Road	Routine	Absent	Absent	1.18	7.62	62	0.069	4	<1		611
	3-Feb-2014	Nguyen	C8	DS 207 Rome Road	Routine	Absent	Absent	1.18	7.61	61	0.073	4	<1		620
	3-Feb-2014	Nguyen	C9	DS Airport Vault	Routine	Absent	Absent	0.92	7.65	57	0.084	3	<1		570
	3-Feb-2014	Nguyen	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.02	7.59	59	0.073	3	<1		608
D	10-Feb-2014	Nguyen	D1	DS-263 Grant Street	Routine	Absent	Absent	1.36	8.01	68	0.082	2	<1	<0.002	509
	10-Feb-2014	Nguyen	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.48	7.39	69	0.083	2	<1	<0.002	785
	10-Feb-2014	Nguyen	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.10	7.84	63	0.093	2	<1	<0.002	485
	10-Feb-2014	Nguyen	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.21	7.99	67	0.087	2	<1	<0.002	488
	10-Feb-2014	Nguyen	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.60	7.33	68	0.162	2	<1	0.002	910
	10-Feb-2014	Jackson	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.04	7.43	57	0.116	2	<1		643
	10-Feb-2014	Jackson	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.12	7.53	60	0.096	3	<1		693
	10-Feb-2014	Jackson	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.03	7.64	61	0.105	3	<1		705
	10-Feb-2014	Jackson	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.19	7.53	63	0.088	2	<1		704
	10-Feb-2014	Jackson	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.13	7.58	64	0.096	3	<1		714
A	18-Feb-2014	West	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.02	7.82	65	0.075	3	<1	<0.002	588
	18-Feb-2014	West	A2	DS-3020 King Circle	Routine	Absent	Absent	0.35	8.06	69	0.063	4	<1	<0.002	489
	18-Feb-2014	West	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.51	7.84	68	0.087	3	<1	<0.002	852
	18-Feb-2014	West	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.52	8.00	69	0.156	3	<1	<0.002	508
	18-Feb-2014	West	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.62	7.77	67	0.085	3	<1	<0.002	577
	18-Feb-2014	Rosales	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.60	7.69	58	0.156	4	<1		530
	18-Feb-2014	Rosales	A7	DS 3570 3rd Street	Routine	Absent	Absent	1.73	7.81	59	0.107	3	<1		535
	18-Feb-2014	Rosales	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.26	7.75	59	0.097	3	<1		594
	18-Feb-2014	Rosales	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.57	7.88	57	0.112	4	<1		529
	18-Feb-2014	Rosales	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.34	7.77	60	0.125	2	<1		603
B	24-Feb-2014	Nguyen	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.91	7.71	63	0.079	3	<1	<0.002	600
	24-Feb-2014	Nguyen	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.08	7.33	64	0.089	4	<1	<0.002	775
	24-Feb-2014	Nguyen	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.97	7.82	73	0.061	3	<1	<0.002	645
	24-Feb-2014	Nguyen	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.80	7.78	70	0.074	3	<1	<0.002	633
	24-Feb-2014	Nguyen	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.00	7.32	70	0.071	3	<1	0.002	921
	24-Feb-2014	Duplissie	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.09	7.40	61	0.081	3	<1		767
	24-Feb-2014	Duplissie	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.21	7.37	55	0.096	3	<1		718
	24-Feb-2014	Duplissie	B8	DS 4235 Giging Road	Routine	Absent	Absent	1.19	7.47	65	0.091	3	<1		696
	24-Feb-2014	Duplissie	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.14	7.52	63	0.102	3	<1		684
	24-Feb-2014	Duplissie	B10	DS Seaside High School	Routine	Absent	Absent	1.14	7.54	57	0.078	3	<1		658
AVERAGE								1.08	7.68	63	0.090	3	<1	<0.002	643
MAXIMUM								1.73	8.06	73	0.162	4	<1	0.002	921
MINIMUM								0.35	7.32	55	0.061	2	<1	<0.002	485

*pH analyzed past 15 minute hold time (all)

**color analyzed past 48 hour hold time (all sampled 2/3/2014)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 MARCH

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.
								RESIDUAL mg/L	Units	TEMP °F	NTU	Color Units	TON	SULFIDE mg/L	COND. @ 25°C µmho/cm
C	3-Mar-2014	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.60	7.87	65	0.087	3	<1	<0.002	519
	3-Mar-2014	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.78	7.98	67	0.084	3	<1	<0.002	491
	3-Mar-2014	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.48	7.57	67	0.082	2	<1	<0.002	623
	3-Mar-2014	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.66	7.72	65	0.079	2	<1	<0.002	602
	3-Mar-2014	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.46	7.49	67	0.080	3	<1	<0.002	732
	3-Mar-2014	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.10	7.43	60	0.075	3	<1		702
	3-Mar-2014	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	1.07	7.40	63	0.090	2	<1		769
	3-Mar-2014	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	1.09	7.37	63	0.082	3	<1		773
	3-Mar-2014	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	1.04	7.36	58	0.098	4	<1		727
	3-Mar-2014	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.04	7.42	60	0.078	3	<1		728
D	10-Mar-2014	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	1.99	8.08	67	0.076	3	<1	<0.002	500
	10-Mar-2014	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.81	7.74	64	0.086	3	<1	<0.002	520
	10-Mar-2014	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.07	7.94	64	0.086	3	<1	<0.002	501
	10-Mar-2014	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	2.01	8.05	64	0.094	3	<1	<0.002	474
	10-Mar-2014	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.51	7.81	67	0.075	3	<1	<0.002	536
	10-Mar-2014	Nguyen	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.15	7.52	58	0.080	3	<1		606
	10-Mar-2014	Nguyen	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.56	7.66	66	0.086	3	<1		539
	10-Mar-2014	Nguyen	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.37	7.70	65	0.124	2	<1		571
	10-Mar-2014	Nguyen	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.41	7.63	65	0.107	3	<1		573
	10-Mar-2014	Nguyen	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.44	7.69	64	0.131	3	<1		572
A	17-Mar-2014	Duplissie	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.41	7.68	63	0.063	3	<1	<0.002	534
	17-Mar-2014	Duplissie	A2	DS-3020 King Circle	Routine	Absent	Absent	1.82	7.90	69	0.069	3	<1	<0.002	548
	17-Mar-2014	Duplissie	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.04	7.31	70	0.077	3	<1	<0.002	815
	17-Mar-2014	Duplissie	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.71	7.80	70	0.089	3	<1	<0.002	611
	17-Mar-2014	Duplissie	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.18	7.28	69	0.082	4	<1	<0.002	783
	17-Mar-2014	Magdalenc	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.17	7.29	68	0.119	4	<1		780
	17-Mar-2014	Magdalenc	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.67	7.69	64	0.119	3	<1		744
	17-Mar-2014	Magdalenc	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.07	7.38	64	0.104	3	<1		760
	17-Mar-2014	Magdalenc	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.86	7.42	62	0.107	4	<1		760
	17-Mar-2014	Magdalenc	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.08	7.57	60	0.082	4	<1		704
B	24-Mar-2014	Duplissie	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.49	7.58	67	0.076	4	<1	<0.002	538
	24-Mar-2014	Duplissie	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.61	7.67	68	0.077	4	<1	<0.002	542
	24-Mar-2014	Duplissie	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.98	7.59	72	0.070	3	<1	0.002	572
	24-Mar-2014	Duplissie	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.31	8.01	73	0.098	3	<1	<0.002	512
	24-Mar-2014	Duplissie	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.60	7.58	71	0.079	3	<1	<0.002	567
	24-Mar-2014	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.21	7.79	67	0.086	3	<1		536
	24-Mar-2014	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.18	7.84	70	0.085	3	<1		551
	24-Mar-2014	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.13	7.73	68	0.532	4	<1		556
	24-Mar-2014	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.05	7.65	66	0.142	4	<1		607
	24-Mar-2014	West	B10	DS Seaside High School	Routine	Absent	Absent	1.10	7.66	67	0.110	3	<1		593
C	31-Mar-2014	Nguyen	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.57	7.64	68	0.070	3	<1	0.002	623
	31-Mar-2014	Nguyen	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.71	7.81	72	0.074	3	<1	0.002	628
	31-Mar-2014	Nguyen	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.64	7.83	69	0.181	3	<1	0.002	613
	31-Mar-2014	Nguyen	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.56	7.80	67	0.153	4	<1	0.004	611
	31-Mar-2014	Nguyen	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.60	7.85	69	0.070	3	<1	0.002	609
	31-Mar-2014	Rosales	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.96	7.56	57	0.080	3	<1		600
	31-Mar-2014	Rosales	C7	DS 325 Buna Road	Routine	Absent	Absent	1.05	7.44	59	0.077	3	<1		684
	31-Mar-2014	Rosales	C8	DS 207 Rome Road	Routine	Absent	Absent	0.78	7.41	56	0.074	3	<1		675
	31-Mar-2014	Rosales	C9	DS Airport Vault	Routine	Absent	Absent	0.59	7.46	61	0.081	3	1		664
	31-Mar-2014	Rosales	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.93	7.51	63	0.104	3	<1		671
AVERAGE								1.17	7.64	65	0.100	3	<1	<0.002	621
MAXIMUM								2.01	8.08	73	0.532	4	1	0.004	815
MINIMUM								0.56	7.28	56	0.063	2	<1	<0.002	474

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 APRIL

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE**	SPEC. COND.
								RESIDUAL	pH Units	*F	NTU	Color Units	TON	mg/L	@ 25°C
								mg/L						mg/L	µmho/cm
D	7-Apr-2014	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	1.27	7.93	63	0.075	3	<1	<0.002	462
	7-Apr-2014	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.20	7.64	62	0.116	3	<1	<0.002	504
	7-Apr-2014	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.16	7.92	58	0.078	3	<1	0.003	426
	7-Apr-2014	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.12	7.82	64	0.107	4	<1	<0.002	491
	7-Apr-2014	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.82	7.53	69	0.072	3	<1	<0.002	568
	7-Apr-2014	Magdalenc	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.98	7.56	58	0.071	3	<1		576
	7-Apr-2014	Magdalenc	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.37	7.64	64	0.070	4	<1		521
	7-Apr-2014	Magdalenc	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.01	7.61	68	0.080	3	<1		602
	7-Apr-2014	Magdalenc	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.15	7.63	58	0.089	3	<1		509
	7-Apr-2014	Magdalenc	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.07	7.65	57	0.070	3	<1		521
A	14-Apr-2014	Magdalenc	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.68	7.84	71	0.079	3	<1	<0.002	615
	14-Apr-2014	Magdalenc	A2	DS-3020 King Circle	Routine	Absent	Absent	0.70	7.77	68	0.063	3	<1	<0.002	634
	14-Apr-2014	Magdalenc	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.78	7.81	73	0.086	4	<1	<0.002	637
	14-Apr-2014	Magdalenc	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.74	7.82	64	0.067	3	<1	<0.002	575
	14-Apr-2014	Magdalenc	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.01	7.30	63	0.115	4	<1	<0.002	775
	14-Apr-2014	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.97	7.31	66	0.599	3	<1		808
	14-Apr-2014	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.37	7.71	64	0.138	3	<1		710
	14-Apr-2014	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.02	7.31	66	0.081	4	<1		770
	14-Apr-2014	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.00	7.35	67	0.073	3	<1		791
	14-Apr-2014	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.07	7.57	66	0.092	3	<1		777
B	21-Apr-2014	Foster	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.38	7.93	74	0.082	3	<1	<0.002	584
	21-Apr-2014	Foster	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.19	7.81	69	0.080	3	<1	<0.002	549
	21-Apr-2014	Foster	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.61	7.48	69	0.101	3	<1	<0.002	777
	21-Apr-2014	Foster	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.28	8.09	71	0.068	3	<1	<0.002	503
	21-Apr-2014	Foster	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.13	7.76	67	0.064	3	<1	<0.002	516
	21-Apr-2014	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.10	7.82	68	0.119	3	<1		587
	21-Apr-2014	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.06	7.59	68	0.219	3	<1		680
	21-Apr-2014	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.16	7.74	68	0.088	3	<1		581
	21-Apr-2014	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.02	7.73	65	0.079	4	<1		605
	21-Apr-2014	West	B10	DS Seaside High School	Routine	Absent	Absent	1.09	7.75	62	0.088	4	<1		595
C	28-Apr-2014	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.99	7.36	68	0.067	3	<1	0.002	779
	28-Apr-2014	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.46	7.57	58	0.073	3	<1	0.002	629
	28-Apr-2014	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.56	7.61	68	0.081	3	<1	0.002	661
	28-Apr-2014	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.63	7.92	65	0.073	3	<1	<0.002	587
	28-Apr-2014	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.09	7.67	68	0.079	3	<1	<0.002	713
	28-Apr-2014	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.99	7.44	66	0.087	3	<1		722
	28-Apr-2014	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	0.96	7.48	63	0.090	3	<1		737
	28-Apr-2014	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	0.99	7.45	65	0.077	2	<1		733
	28-Apr-2014	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	0.56	7.50	61	0.075	3	<1		697
	28-Apr-2014	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.97	7.51	62	0.093	4	<1		694
AVERAGE								0.99	7.65	65	0.100	3	<1	<0.002	630
MAXIMUM								1.61	8.09	74	0.599	4	<1	0.003	808
MINIMUM								0.37	7.30	57	0.063	2	<1	<0.002	426

*pH analyzed past 15 minute hold time (all)

**total sulfide results (14-Apr-2014 sampling) exceeded % difference QC limits

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 MAY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE RESIDUAL	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C		
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm		
D	5-May-2014	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	1.03	7.99	71	0.064	3	<1	0.002	497		
	5-May-2014	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.43	7.67	67	0.080	3	<1	<0.002	545		
	5-May-2014	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.17	7.92	70	0.087	3	<1	<0.002	499		
	5-May-2014	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.53	7.83	68	0.090	3	<1	<0.002	526		
	5-May-2014	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.12	7.57	70	0.066	3	<1	<0.002	578		
	5-May-2014	West	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.32	7.44	66	0.078	2	<1		641		
	5-May-2014	West	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.64	7.57	69	0.087	1	<1		557		
	5-May-2014	West	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.05	7.62	70	0.103	2	<1		570		
	5-May-2014	West	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.25	7.44	62	0.079	2	<1		531		
	5-May-2014	West	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.20	7.65	62	0.078	2	<1		532		
A	12-May-2014	Jackson	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.91	7.86	66	0.072	4	<1	<0.002	597		
	12-May-2014	Jackson	A2	DS-3020 King Circle	Routine	Absent	Absent	0.87	7.72	73	0.086	4	<1	<0.002	717		
	12-May-2014	Jackson	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.14	7.97	76	0.081	3	<1	<0.002	662		
	12-May-2014	Jackson	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.90	7.86	74	0.078	4	<1	<0.002	675		
	12-May-2014	Jackson	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.85	7.38	69	0.082	3	<1	<0.002	824		
	12-May-2014	Rodriguez	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.92	7.22	61	0.119	3	<1		720		
	12-May-2014	Rodriguez	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.56	7.65	62	0.092	4	<1		681		
	12-May-2014	Rodriguez	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.85	7.36	67	0.099	3	<1		793		
	12-May-2014	Rodriguez	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.70	7.45	66	0.092	4	<1		732		
	12-May-2014	Rodriguez	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.93	7.46	70	0.071	4	<1		815		
B	19-May-2014	Jackson	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.05	8.02	66	0.092	3	<1	<0.002	473		
	19-May-2014	Jackson	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.11	7.77	64	0.107	3	<1	<0.002	510		
	19-May-2014	Jackson	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.08	7.69	70	0.079	3	<1	<0.002	562		
	19-May-2014	Jackson	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.06	8.09	70	0.127	4	<1	0.002	482		
	19-May-2014	Jackson	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.87	7.63	64	0.068	3	<1	0.003	521		
	19-May-2014	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.12	7.62	69	0.069	2	<1		609		
	19-May-2014	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.12	7.70	67	0.093	3	<1		530		
	19-May-2014	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.95	7.73	69	0.138	3	<1		544		
	19-May-2014	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.12	7.72	67	0.078	3	1		537		
	19-May-2014	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	1.05	7.71	72	0.068	3	<1		564		
C	27-May-2014	Jackson	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.92	7.31	68	0.075	4	<1	<0.002	745		
	27-May-2014	Jackson	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.10	7.34	68	0.085	4	<1	<0.002	763		
	27-May-2014	Jackson	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.99	7.38	68	0.072	3	<1	<0.002	760		
	27-May-2014	Jackson	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.10	7.84	70	0.071	4	<1	<0.002	623		
	27-May-2014	Jackson	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.96	7.59	73	0.070	3	<1	<0.002	759		
	27-May-2014	Rosales	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.90	7.43	59	0.075	4	<1		679		
	27-May-2014	Rosales	C7	DS 325 Buna Road	Routine	Absent	Absent	1.16	7.44	59	0.085	5	<1		682		
	27-May-2014	Rosales	C8	DS 207 Rome Road	Routine	Absent	Absent	1.47	7.40	67	0.110	2	<1		778		
	27-May-2014	Rosales	C9	DS Airport Vault	Routine	Absent	Absent	0.66	7.39	66	0.075	3	<1		717		
	27-May-2014	Rosales	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.97	7.52	67	0.083	2	<1		737		
AVERAGE																	
MAXIMUM																	
MINIMUM																	

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 JUNE

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°c
								RESIDUAL	mg/L	pH Units	°F	NTU	Color Units	TON	mg/L
D	2-Jun-2014	Jackson	D1	DS-263 Grant Street	Routine	Absent	Absent	0.64	8.07	71	0.109	3	<1	<0.002	491
	2-Jun-2014	Jackson	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.08	7.66	71	0.107	3	<1	<0.002	567
	2-Jun-2014	Jackson	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.38	7.89	71	0.103	3	<1	<0.002	524
	2-Jun-2014	Jackson	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.08	7.78	71	0.084	3	<1	<0.002	567
	2-Jun-2014	Jackson	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.07	7.67	70	0.093	3	<1	<0.002	579
	2-Jun-2014	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.81	7.59	56	0.135	3	<1		523
	2-Jun-2014	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.01	7.64	64	0.109	3	<1		527
	2-Jun-2014	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.01	7.66	69	0.115	4	<1		566
	2-Jun-2014	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.25	7.71	68	0.116	4	<1		555
	2-Jun-2014	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.07	7.73	69	0.113	3	<1		568
A	9-Jun-2014	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.06	7.82	65	0.118	2	<1	<0.002	593
	9-Jun-2014	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	0.99	7.78	66	0.094	4	<1	<0.002	582
	9-Jun-2014	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.60	7.88	66	0.082	3	<1	<0.002	604
	9-Jun-2014	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.34	7.81	70	0.067	3	<1	<0.002	612
	9-Jun-2014	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.85	7.31	66	0.084	3	<1	<0.002	805
	9-Jun-2014	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.00	7.38	69	0.158	4	<1		820
	9-Jun-2014	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.37	7.61	65	0.234	2	<1		676
	9-Jun-2014	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.01	7.38	69	0.106	2	<1		801
	9-Jun-2014	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.03	7.35	70	0.100	3	<1		825
	9-Jun-2014	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.91	7.30	71	0.111	2	<1		842
B	16-Jun-2014	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.89	7.98	65	0.081	2	<1	<0.002	487
	16-Jun-2014	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.17	7.71	68	0.076	2	<1	<0.002	558
	16-Jun-2014	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.48	7.61	71	0.084	3	<1	<0.002	594
	16-Jun-2014	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.85	8.06	65	0.090	3	<1	<0.002	474
	16-Jun-2014	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.80	7.62	68	0.075	2	<1	<0.002	569
	16-Jun-2014	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.36	7.71	66	0.078	3	<1		547
	16-Jun-2014	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.24	7.65	69	0.080	2	<1		562
	16-Jun-2014	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.21	7.67	64	0.071	3	<1		539
	16-Jun-2014	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.31	7.62	70	0.082	2	<1		577
	16-Jun-2014	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	1.28	7.60	70	0.079	3	<1		576
C	23-Jun-2014	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.25	7.97	73	0.082	3	<1	<0.002	795
	23-Jun-2014	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.30	7.69	69	0.116	3	<1	<0.002	769
	23-Jun-2014	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.24	7.77	71	0.124	3	<1	<0.002	783
	23-Jun-2014	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.83	7.75	67	0.089	4	<1	<0.002	625
	23-Jun-2014	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.96	7.79	67	0.093	4	<1	<0.002	579
	23-Jun-2014	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.05	7.33	64	0.094	4	<1		686
	23-Jun-2014	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	1.04	7.33	67	0.076	3	<1		738
	23-Jun-2014	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	0.99	7.36	66	0.133	4	<1		709
	23-Jun-2014	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.75	7.34	68	0.100	3	1		708
	23-Jun-2014	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.06	7.22	65	0.126	3	<1		742
D	30-Jun-2014	Jackson	D1	DS-263 Grant Street	Routine	Absent	Absent	0.73	8.01	72	0.110	4	<1	<0.002	506
	30-Jun-2014	Jackson	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.02	7.66	71	0.072	2	<1	<0.002	565
	30-Jun-2014	Jackson	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.99	7.93	71	0.083	2	<1	<0.002	492
	30-Jun-2014	Jackson	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.34	7.76	69	0.081	2	<1	0.002	544
	30-Jun-2014	Jackson	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.25	7.71	67	0.069	2	<1	0.002	509
	30-Jun-2014	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.23	7.57	68	0.096	2	<1		569
	30-Jun-2014	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.27	7.59	69	0.066	3	<1		557
	30-Jun-2014	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.20	7.60	71	0.069	2	<1		568
	30-Jun-2014	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.30	7.66	67	0.103	3	<1		576
	30-Jun-2014	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.24	7.68	67	0.079	2	<1		549
AVERAGE								1.08	7.66	68	0.098	3	<1	<0.002	614
MAXIMUM								1.81	8.07	73	0.234	4	1	0.002	842
MINIMUM								0.37	7.22	56	0.066	2	<1	<0.002	474

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 JULY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.
								RESIDUAL	mg/L	pH Units	TEMP	NTU	Color Units	TON	SULFIDE
A	7-Jul-2014	Foster	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.12	7.22	72	0.065	3	<1	<0.002	917
	7-Jul-2014	Foster	A2	DS-3020 King Circle	Routine	Absent	Absent	1.25	7.27	67	0.062	2	<1	<0.002	760
	7-Jul-2014	Foster	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.47	7.24	67	0.115	2	<1	<0.002	754
	7-Jul-2014	Foster	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.26	7.27	64	0.063	2	<1	<0.002	733
	7-Jul-2014	Foster	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.69	7.30	68	0.074	2	<1	<0.002	767
	7-Jul-2014	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.22	7.44	66	0.084	2	1		644
	7-Jul-2014	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.68	7.74	65	0.144	2	<1		684
	7-Jul-2014	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.27	7.32	69	0.090	2	<1		780
	7-Jul-2014	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.27	7.31	67	0.134	1	<1		760
	7-Jul-2014	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.26	7.36	63	0.123	2	<1		717
B	14-Jul-2014	Jackson	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.60	7.93	72	0.090	2	<1	<0.002	634
	14-Jul-2014	Jackson	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.19	7.68	66	0.094	2	<1	<0.002	564
	14-Jul-2014	Jackson	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.68	7.95	75	0.097	1	<1	<0.002	657
	14-Jul-2014	Jackson	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.48	7.91	71	0.087	2	<1	<0.002	637
	14-Jul-2014	Jackson	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.78	7.98	78	0.132	3	<1	<0.002	685
	14-Jul-2014	Rosales	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.18	7.74	69	0.125	2	<1		643
	14-Jul-2014	Rosales	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.30	7.75	71	0.099	1	<1		590
	14-Jul-2014	Rosales	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.23	7.70	69	0.122	3	<1		588
	14-Jul-2014	Rosales	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.44	7.72	68	0.090	2	<1		575
	14-Jul-2014	Rosales	B10	DS Seaside High School	Routine	Absent	Absent	1.14	7.71	71	0.092	2	<1		594
C	21-Jul-2014	Rodriguez	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.19	7.35	61	0.079	2	<1	<0.002	728
	21-Jul-2014	Rodriguez	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.26	7.34	58	0.066	3	<1	<0.002	685
	21-Jul-2014	Rodriguez	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.27	7.33	66	0.082	3	<1	<0.002	747
	21-Jul-2014	Rodriguez	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.97	7.78	68	0.087	3	<1	<0.002	631
	21-Jul-2014	Rodriguez	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.18	7.53	75	0.090	2	<1	<0.002	795
	21-Jul-2014	Kelsey	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.22	7.38	67	0.101	2	<1		769
	21-Jul-2014	Kelsey	C7	DS 325 Buna Road	Routine	Absent	Absent	1.14	7.44	69	0.071	3	<1		783
	21-Jul-2014	Kelsey	C8	DS 207 Rome Road	Routine	Absent	Absent	1.24	7.53	67	0.083	2	<1		758
	21-Jul-2014	Kelsey	C9	DS Airport Vault	Routine	Absent	Absent	0.67	7.46	71	0.074	3	<1		782
	21-Jul-2014	Kelsey	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.29	7.33	71	0.077	3	<1		819
D	28-Jul-2014	West	D1	DS-263 Grant Street	Routine	Absent	Absent	1.43	8.06	76	0.085	2	<1	<0.002	527
	28-Jul-2014	West	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.62	7.67	73	0.098	2	<1	<0.002	581
	28-Jul-2014	West	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.14	7.89	75	0.099	2	<1	<0.002	550
	28-Jul-2014	West	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.52	7.79	73	0.105	1	<1	<0.002	579
	28-Jul-2014	West	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.42	7.59	72	0.080	2	<1	<0.002	603
	28-Jul-2014	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.32	7.64	68	0.112	2	<1		567
	28-Jul-2014	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.32	7.62	71	0.085	3	<1		583
	28-Jul-2014	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.35	7.68	65	0.146	2	<1		522
	28-Jul-2014	Duplissie	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.41	7.66	73	0.063	2	<1		589
	28-Jul-2014	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.34	7.71	69	0.091	2	<1		569
AVERAGE								1.20	7.58	69	0.09	2	<1	<0.002	671
MAXIMUM								1.69	8.06	78	0.15	3	1	<0.002	917
MINIMUM								0.48	7.22	58	0.062	1	<1	<0.002	522

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 AUGUST

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
A	4-Aug-2014	Jackson	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.87	7.73	72	0.090	2	<1	<0.002	630
	4-Aug-2014	Jackson	A2	DS-3020 King Circle	Routine	Absent	Absent	1.01	7.77	73	0.099	3	<1	<0.002	674
	4-Aug-2014	Jackson	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.15	7.95	73	0.069	3	<1	<0.002	636
	4-Aug-2014	Jackson	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.06	7.89	75	0.070	3	<1	<0.002	667
	4-Aug-2014	Jackson	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.05	7.46	72	0.100	3	<1	<0.002	839
	4-Aug-2014	Rodriguez	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.89	7.36	67	0.087	3	<1		743
	4-Aug-2014	Rodriguez	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.75	7.74	68	0.130	3	<1		733
	4-Aug-2014	Rodriguez	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.04	7.38	64	0.126	4	<1		758
	4-Aug-2014	Rodriguez	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.99	7.49	63	0.105	3	<1		728
	4-Aug-2014	Rodriguez	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.97	7.55	70	0.123	4	<1		826
B	11-Aug-2014	Jackson	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.14	7.95	73	0.140	3	<1	<0.002	520
	11-Aug-2014	Jackson	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.29	7.70	71	0.119	2	<1	<0.002	574
	11-Aug-2014	Jackson	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.19	7.66	70	0.186	3	<1	0.002	580
	11-Aug-2014	Jackson	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.20	8.06	71	0.169	3	<1	<0.002	494
	11-Aug-2014	Jackson	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.08	7.64	67	0.105	3	<1	<0.002	550
	11-Aug-2014	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.01	7.74	61	0.130	3	<1		590
	11-Aug-2014	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.24	7.67	69	0.114	3	<1		553
	11-Aug-2014	Rodriguez	B8	DS 4235 Gigung Road	Routine	Absent	Absent	1.07	7.62	68	0.173	3	<1		596
	11-Aug-2014	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.13	7.65	69	0.157	3	<1		563
	11-Aug-2014	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	1.02	7.68	73	0.113	3	<1		583
C	18-Aug-2014	Jackson	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.08	7.87	70	0.131	3	<1	<0.002	623
	18-Aug-2014	Jackson	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.16	7.93	75	0.095	3	<1	<0.002	665
	18-Aug-2014	Jackson	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.12	7.96	75	0.103	5	<1	<0.002	663
	18-Aug-2014	Jackson	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.94	7.92	71	0.097	3	<1	<0.002	641
	18-Aug-2014	Jackson	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.10	8.02	76	0.094	4	<1	<0.002	674
	18-Aug-2014	Foster	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.50	7.43	69	0.107	4	<1		799
	18-Aug-2014	Foster	C7	DS 325 Buna Road	Routine	Absent	Absent	1.15	7.50	69	0.115	4	<1		786
	18-Aug-2014	Foster	C8	DS 207 Rome Road	Routine	Absent	Absent	1.23	7.43	70	0.100	3	<1		810
	18-Aug-2014	Foster	C9	DS Airport Vault	Routine	Absent	Absent	0.57	7.45	72	0.119	4	<1		801
	18-Aug-2014	Foster	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.27	7.43	70	0.125	3	<1		813
D	25-Aug-2014	Jackson	D1	DS-263 Grant Street	Routine	Absent	Absent	1.49	8.08	74	0.134	3	<1	<0.002	504
	25-Aug-2014	Jackson	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.10	7.72	68	0.083	3	<1	<0.002	545
	25-Aug-2014	Jackson	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.26	7.93	74	0.074	2	<1	<0.002	558
	25-Aug-2014	Jackson	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.14	7.79	71	0.089	3	<1	<0.002	562
	25-Aug-2014	Jackson	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.05	7.67	74	0.071	2	<1	<0.002	602
	25-Aug-2014	Foster	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.87	7.63	73	0.096	3	<1		673
	25-Aug-2014	Foster	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.43	7.65	73	0.068	3	<1		563
	25-Aug-2014	Foster	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.23	7.65	75	0.066	3	<1		597
	25-Aug-2014	Foster	D9	DS 110 Nijmegen Road	Routine	Present	Absent	1.16	7.67	70	0.057	3	<1		570
	25-Aug-2014	Foster	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.22	7.68	71	0.066	3	<1		592
	26-Aug-2014	West	D9	DS 110 Nijmegen Road	Repeat	Absent	Absent	0.81							
	26-Aug-2014	West	D9u	DS 201 Nijmegen Road	Repeat	Absent	Absent	0.92							
	26-Aug-2014	West	D9d	DS 108 Nijmegen Road	Repeat	Absent	Absent	0.76							
AVERAGE								1.11	7.70	71	0.107	3	<1	<0.002	647
MAXIMUM								1.50	8.08	76	0.186	5	<1	0.002	839
MINIMUM								0.57	7.36	61	0.057	2	<1	<0.002	494

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 SEPTEMBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL mg/L	pH Units	*F	NTU	Color Units	TON	mg/L	µmho/cm
A	2-Sep-2014	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.90	7.58	60	0.104	3	<1	<0.002	582
	2-Sep-2014	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	0.97	7.41	56	0.119	4	<1	<0.002	665
	2-Sep-2014	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.03	7.32	57	0.761	4	<1	0.003	672
	2-Sep-2014	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.97	7.37	59	0.100	4	<1	<0.002	685
	2-Sep-2014	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.92	7.40	67	0.142	3	<1	<0.002	766
	2-Sep-2014	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.23	7.28	65	0.126	3	<1		755
	2-Sep-2014	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.59	7.75	65	0.115	2	<1		738
	2-Sep-2014	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.13	7.35	68	0.165	3	<1		776
	2-Sep-2014	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.04	7.47	64	0.121	3	<1		747
	2-Sep-2014	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.97	7.57	69	0.119	4	<1		782
B	8-Sep-2014	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.58	7.99	72	0.092	3	<1	0.002	508
	8-Sep-2014	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.40	7.75	72	0.100	3	<1	0.005	574
	8-Sep-2014	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.40	7.68	75	0.078	4	<1	<0.002	612
	8-Sep-2014	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.45	8.13	75	0.084	4	<1	0.002	522
	8-Sep-2014	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.89	7.65	73	0.091	3	<1	0.003	594
	8-Sep-2014	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.38	7.85	61	0.075	3	<1		512
	8-Sep-2014	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.46	7.77	64	0.094	3	<1		525
	8-Sep-2014	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.34	7.69	64	0.069	3	<1		538
	8-Sep-2014	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.26	7.62	61	0.074	3	<1		590
	8-Sep-2014	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	1.39	7.67	67	0.081	3	<1		552
C	15-Sep-2014	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.00	7.84	74	0.088	3	<1	<0.002	658
	15-Sep-2014	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.33	7.90	74	0.177	3	<1	<0.002	652
	15-Sep-2014	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.28	7.92	77	0.089	3	<1	<0.002	683
	15-Sep-2014	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	2.20	7.95	74	0.077	2	<1	<0.002	659
	15-Sep-2014	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.16	7.94	78	0.086	3	<1	<0.002	697
	15-Sep-2014	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.07	7.44	65	0.103	4	<1		713
	15-Sep-2014	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	1.06	7.48	69	0.097	2	<1		791
	15-Sep-2014	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	1.63	7.51	60	0.085	4	<1		713
	15-Sep-2014	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.60	7.58	69	0.069	3	<1		777
	15-Sep-2014	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.10	7.50	67	0.083	4	<1		752
D	22-Sep-2014	Nguyen	D1	DS-263 Grant Street	Routine	Absent	Absent	0.93	7.91	71	0.093	3	<1	<0.002	495
	22-Sep-2014	Nguyen	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.30	7.65	72	0.097	3	<1	<0.002	580
	22-Sep-2014	Nguyen	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.84	7.76	76	0.062	3	<1	<0.002	529
	22-Sep-2014	Nguyen	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.77	7.88	68	0.063	4	<1	0.002	515
	22-Sep-2014	Nguyen	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.43	7.73	71	0.084	3	<1	<0.002	586
	22-Sep-2014	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.38	7.65	71	0.062	2	<1		578
	22-Sep-2014	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.38	7.69	65	0.092	1	<1		553
	22-Sep-2014	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.31	7.78	73	0.084	2	<1		580
	22-Sep-2014	Duplissie	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.21	7.81	73	0.067	3	<1		583
	22-Sep-2014	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.35	7.73	73	0.084	2	<1		612
A	29-Sep-2014	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.22	7.93	74	0.197	2	<1	<0.002	674
	29-Sep-2014	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	0.93	7.84	72	0.124	1	<1	<0.002	679
	29-Sep-2014	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.13	7.92	74	0.129	2	<1	<0.002	676
	29-Sep-2014	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.93	7.87	69	0.112	3	<1	<0.002	647
	29-Sep-2014	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.96	7.40	73	0.101	2	<1	<0.002	894
	29-Sep-2014	Nguyen	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.13	7.42	66	0.325	2	<1		791
	29-Sep-2014	Nguyen	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.93	7.60	69	0.138	3	<1		782
	29-Sep-2014	Nguyen	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.18	7.48	71	0.137	1	<1		852
	29-Sep-2014	Nguyen	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.05	7.46	71	0.089	1	<1		838
	29-Sep-2014	Nguyen	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.39	7.90	70	0.116	3	<1		830
AVERAGE								1.17	7.68	69	0.118	3	<1	<0.002	661
MAXIMUM								2.20	8.13	78	0.761	4	<1	0.005	894
MINIMUM								0.59	7.28	56	0.062	1	<1	<0.002	495

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 OCTOBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL mg/L	pH Units	*F	NTU	Color Units	TON	mg/L	µmho/cm
B	6-Oct-2014	Magdaleno	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.45	8.01	60	0.090	3	<1	<0.002	443
	6-Oct-2014	Magdaleno	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.60	7.72	62	0.074	4	<1	<0.002	520
	6-Oct-2014	Magdaleno	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.63	7.65	72	0.088	4	<1	<0.002	607
	6-Oct-2014	Magdaleno	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.55	8.11	61	0.113	4	<1	0.002	440
	6-Oct-2014	Magdaleno	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.99	7.62	67	0.091	3	<1	0.002	575
	6-Oct-2014	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.16	7.70	70	0.083	3	<1		572
	6-Oct-2014	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.31	7.62	70	0.115	3	<1		567
	6-Oct-2014	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.39	7.72	63	0.345	3	<1		535
	6-Oct-2014	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.70	7.63	69	0.072	3	<1		584
	6-Oct-2014	West	B10	DS Seaside High School	Routine	Absent	Absent	1.10	7.69	70	0.102	2	<1		567
C	13-Oct-2014	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.30	7.79	74	0.080	1	<1	0.002	675
	13-Oct-2014	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.33	7.91	77	0.109	2	<1	0.002	695
	13-Oct-2014	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.37	7.96	74	0.150	3	<1	0.003	667
	13-Oct-2014	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.15	7.96	73	0.088	1	<1	0.002	668
	13-Oct-2014	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.28	7.98	73	0.089	2	<1	<0.002	666
	13-Oct-2014	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.16	7.34	71	0.084	1	<1		781
	13-Oct-2014	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	1.17	7.43	69	0.103	2	<1		810
	13-Oct-2014	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	1.15	7.42	68	0.076	2	<1		809
	13-Oct-2014	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	0.58	7.44	65	0.114	2	<1		782
	13-Oct-2014	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.16	7.34	69	0.112	2	<1		827
D	20-Oct-2014	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	1.43	7.93	66	0.183	1	<1	<0.002	485
	20-Oct-2014	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.38	7.55	65	0.090	1	<1	0.002	557
	20-Oct-2014	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	2.23	7.63	68	0.093	1	<1	<0.002	554
	20-Oct-2014	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.29	7.60	70	0.315	1	<1	<0.002	553
	20-Oct-2014	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.23	7.59	73	0.111	1	<1	<0.002	607
	20-Oct-2014	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.18	7.43	69	0.096	1	<1		563
	20-Oct-2014	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.54	7.57	70	0.167	1	<1		477
	20-Oct-2014	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.45	7.61	70	0.088	1	<1		484
	20-Oct-2014	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.58	7.65	71	0.090	1	<1		500
	20-Oct-2014	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.47	7.63	73	0.070	2	<1		625
A	27-Oct-2014	Nguyen	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.86	7.73	70	0.093	1	<1	0.005	586
	27-Oct-2014	Nguyen	A2	DS-3020 King Circle	Routine	Absent	Absent	0.71	7.50	71	0.086	1	<1	0.007	600
	27-Oct-2014	Nguyen	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.89	7.72	74	0.146	1	<1	0.005	631
	27-Oct-2014	Nguyen	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.91	7.70	70	0.076	2	<1	0.014	640
	27-Oct-2014	Nguyen	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.16	7.29	70	0.095	2	<1	0.010	849
	27-Oct-2014	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.28	7.26	61	0.080	2	<1		830
	27-Oct-2014	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	1.10	7.47	67	0.101	1	<1		749
	27-Oct-2014	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.55	7.45	66	0.081	1	<1		768
	27-Oct-2014	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.30	7.41	65	0.087	1	<1		755
	27-Oct-2014	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.31	7.72	64	0.104	1	<1		728
AVERAGE								1.31	7.64	69	0.111	2	<1	0.003	633
MAXIMUM								2.23	8.11	77	0.345	4	<1	0.014	849
MINIMUM								0.58	7.26	60	0.070	1	<1	<0.002	440

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 NOVEMBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.	
								RESIDUAL	mg/L	pH Units	TEMP	NTU	Color Units	TON	SULFIDE	@ 25°c
								mg/L		°F					µmho/cm	
B	3-Nov-2014	Duplissie	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.71	7.44	72	0.087	1	<1	<0.002	582	
	3-Nov-2014	Duplissie	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.09	7.65	72	0.134	1	<1	<0.002	560	
	3-Nov-2014	Duplissie	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.63	7.86	70	0.133	1	<1	0.002	525	
	3-Nov-2014	Duplissie	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.93	7.71	68	0.110	3	<1	<0.002	556	
	3-Nov-2014	Duplissie	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.15	7.60	70	0.155	1	<1	<0.002	564	
	3-Nov-2014	Jackson	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.26	7.80	64	0.128	3	<1		553	
	3-Nov-2014	Jackson	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.00	7.65	62	0.095	2	<1		577	
	3-Nov-2014	Jackson	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.10	7.63	62	0.093	2	<1		563	
	3-Nov-2014	Jackson	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.09	7.59	62	0.097	1	<1		634	
	3-Nov-2014	Jackson	B10	DS Seaside High School	Routine	Absent	Absent	1.00	7.60	67	0.273	2	<1		630	
C	12-Nov-2014	Nguyen	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.29	7.49	70	0.111	3	<1	<0.002	608	
	12-Nov-2014	Nguyen	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.26	7.70	68	0.183	3	<1	<0.002	559	
	12-Nov-2014	Nguyen	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.11	7.70	69	0.258	4	<1	0.003	569	
	12-Nov-2014	Nguyen	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.43	7.83	69	0.230	3	<1	0.003	584	
	12-Nov-2014	Nguyen	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.10	7.99	71	0.170	4	<1	0.003	506	
	12-Nov-2014	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.69	7.60	68	0.390	3	<1		733	
	12-Nov-2014	West	C7	DS 325 Buna Road	Routine	Absent	Absent	0.81	7.58	67	0.225	3	<1		799	
	12-Nov-2014	West	C8	DS 207 Rome Road	Routine	Absent	Absent	0.63	7.56	64	0.125	2	<1		760	
	12-Nov-2014	West	C9	DS Airport Vault	Routine	Absent	Absent	0.60	7.57	67	0.085	4	<1		788	
	12-Nov-2014	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.49	7.52	69	0.125	3	<1		736	
D	17-Nov-2014	Jackson	D1	DS-263 Grant Street	Routine	Absent	Absent	1.18	7.44	64	0.104	1	<1	<0.002	585	
	17-Nov-2014	Jackson	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.16	7.59	64	0.127	2	<1	<0.002	551	
	17-Nov-2014	Jackson	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.08	7.86	66	0.098	2	<1	<0.002	541	
	17-Nov-2014	Jackson	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.29	7.93	69	0.103	1	<1	0.003	530	
	17-Nov-2014	Jackson	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.21	7.72	70	0.080	1	<1	<0.002	566	
	17-Nov-2014	Rosales	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.17	7.37	66	0.070	1	<1		627	
	17-Nov-2014	Rosales	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.15	7.57	66	0.103	2	<1		604	
	17-Nov-2014	Rosales	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.25	7.56	67	0.126	2	<1		565	
	17-Nov-2014	Rosales	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.19	7.60	66	0.093	2	<1		559	
	17-Nov-2014	Rosales	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.05	7.61	68	0.105	2	<1		600	
A	24-Nov-2014	Foster	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.83	7.94	69	0.105	1	<1	0.003	628	
	24-Nov-2014	Foster	A2	DS-3020 King Circle	Routine	Absent	Absent	0.72	7.85	69	0.095	2	<1	0.002	635	
	24-Nov-2014	Foster	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.96	7.91	71	0.156	3	<1	0.003	627	
	24-Nov-2014	Foster	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.00	7.88	71	0.090	2	<1	0.002	627	
	24-Nov-2014	Foster	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.89	7.43	68	0.111	1	<1	0.003	810	
	24-Nov-2014	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.81	7.35	69	0.106	2	<1		833	
	24-Nov-2014	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.64	7.61	65	0.133	2	<1		768	
	24-Nov-2014	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.21	7.59	64	0.125	2	<1		699	
	24-Nov-2014	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.06	7.56	62	0.086	2	<1		783	
	24-Nov-2014	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.68	7.64	65	0.750	1	<1		712	
AVERAGE																
MAXIMUM																
MINIMUM																
								0.97	7.65	67	0.149	2	<1	<0.002	631	
								1.29	7.99	72	0.750	4	<1	0.003	833	
								0.43	7.35	62	0.070	1	<1	<0.002	506	

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2014 DECEMBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE RESIDUAL mg/L	pH* pH Units	LAB TEMP °F	TURBIDITY NTU	COLOR Color Units	ODOR TON	TOTAL SULFIDE mg/L	SPEC. COND. @ 25°c umho/cm
B	1-Dec-2014	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.25	8.07	67	0.132	3	<1	0.005	502
	1-Dec-2014	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.23	7.70	67	0.107	2	<1	0.004	624
	1-Dec-2014	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.23	8.02	71	0.098	2	<1	0.006	524
	1-Dec-2014	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.32	8.13	69	0.127	2	<1	0.003	503
	1-Dec-2014	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.28	7.80	68	0.121	1	<1	0.003	574
	1-Dec-2014	Foster	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.37	7.71	71	0.128	2	<1		572
	1-Dec-2014	Foster	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.24	7.62	69	0.116	3	<1		645
	1-Dec-2014	Foster	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.39	7.64	72	0.140	2	<1		572
	1-Dec-2014	Foster	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.01	7.57	68	0.151	3	<1		710
	1-Dec-2014	Foster	B10	DS Seaside High School	Routine	Absent	Absent	1.07	7.65	69	0.109	3	<1		688
C	8-Dec-2014	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.97	7.87	70	0.078	3	<1	0.004	615
	8-Dec-2014	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.80	7.78	72	0.086	3	<1	0.008	691
	8-Dec-2014	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.96	7.98	68	0.111	2	<1	0.003	606
	8-Dec-2014	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.97	7.95	77	0.085	3	<1	0.002	603
	8-Dec-2014	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.85	7.99	76	0.109	3	<1	0.003	607
	8-Dec-2014	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.56	7.57	63	0.151	2	<1		680
	8-Dec-2014	West	C7	DS 325 Buna Road	Routine	Absent	Absent	0.53	7.52	63	0.091	3	<1		734
	8-Dec-2014	West	C8	DS 207 Rome Road	Routine	Absent	Absent	0.60	7.47	62	0.129	3	<1		782
	8-Dec-2014	West	C9	DS Airport Vault	Routine	Absent	Absent	0.46	7.59	63	0.085	2	<1		671
	8-Dec-2014	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.43	7.57	62	0.135	1	<1		674
D	15-Dec-2014	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	1.76	7.16	64	0.135	2	<1	0.004	879
	15-Dec-2014	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.82	7.45	64	0.095	1	<1	0.006	559
	15-Dec-2014	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.04	7.91	64	0.126	2	<1	0.003	491
	15-Dec-2014	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.15	7.99	64	0.096	3	<1	0.002	472
	15-Dec-2014	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.06	8.06	67	0.103	2	<1	0.004	479
	15-Dec-2014	Magdalenc	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.02	7.68	61	0.099	2	<1		592
	15-Dec-2014	Magdalenc	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.02	7.61	62	0.120	2	<1		585
	15-Dec-2014	Magdalenc	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.88	7.58	62	0.118	1	<1		605
	15-Dec-2014	Magdalenc	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.87	7.62	60	0.082	2	<1		583
	15-Dec-2014	Magdalenc	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.00	7.63	59	0.103	1	<1		571
A	22-Dec-2014	Duplissie	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.14	7.84	65	0.131	3	<1	0.003	585
	22-Dec-2014	Duplissie	A2	DS-3020 King Circle	Routine	Absent	Absent	1.09	7.78	67	0.119	3	<1	<0.002	656
	22-Dec-2014	Duplissie	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.23	7.86	76	0.101	3	<1	<0.002	657
	22-Dec-2014	Duplissie	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.14	7.88	70	0.311	3	<1	<0.002	632
	22-Dec-2014	Duplissie	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.09	7.51	67	0.085	3	<1	<0.002	755
	22-Dec-2014	Jackson	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.48	7.48	61	0.154	3	<1		748
	22-Dec-2014	Jackson	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.56	7.62	59	0.217	4	<1		757
	22-Dec-2014	Jackson	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.74	7.58	60	0.118	3	<1		664
	22-Dec-2014	Jackson	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.86	7.60	63	0.093	3	<1		743
	22-Dec-2014	Jackson	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.69	7.61	65	0.167	3	<1		687
B	29-Dec-2014	Nguyen	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.43	8.01	64	0.098	3	<1	<0.002	466
	29-Dec-2014	Nguyen	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.27	7.66	61	0.085	3	<1	<0.002	613
	29-Dec-2014	Nguyen	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.37	8.02	66	0.115	4	<1	<0.002	483
	29-Dec-2014	Nguyen	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.51	8.10	64	0.082	3	<1	0.002	476
	29-Dec-2014	Nguyen	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.40	8.09	65	0.105	4	<1	<0.002	479
	29-Dec-2014	Rosales	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.20	7.79	63	0.093	3	<1		539
	29-Dec-2014	Rosales	B7	DS 6th Avenue 53	Routine	Absent	Absent	2.01	7.75	62	0.115	3	<1		533
	29-Dec-2014	Rosales	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.48	7.68	59	0.243	3	<1		535
	29-Dec-2014	Rosales	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.35	7.66	60	0.090	3	<1		644
	29-Dec-2014	Rosales	B10	DS Seaside High School	Routine	Absent	Absent	1.00	7.64	59	0.089	3	<1		662
AVERAGE								1.10	7.74	65	0.120	3	<1	0.003	614
MAXIMUM								2.01	8.13	77	0.311	4	<1	0.008	879
MINIMUM								0.43	7.16	59	0.078	1	<1	<0.002	466

*pH analyzed past 15 minute hold time (all)