

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 JANUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.
								RESIDUAL	mg/L	pH Units	TEMP	NTU	Color Units	TON	SULFIDE
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
C	4-Jan-2016	Foster	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.31	7.88	61	0.130	4	<1	<0.002	532
	4-Jan-2016	Foster	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.85	7.93	70	0.083	5	<1	<0.002	627
	4-Jan-2016	Foster	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.39	7.95	63	0.137	3	<1	<0.002	569
	4-Jan-2016	Foster	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.37	7.98	59	0.144	3	<1	<0.002	543
	4-Jan-2016	Foster	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.35	7.98	61	0.118	4	<1	<0.002	553
	4-Jan-2016	Nguyen	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.32	7.75	57	0.111	4	1		611
	4-Jan-2016	Nguyen	C7	DS 325 Buna Road	Routine	Absent	Absent	1.52	7.85	58	0.100	3	<1		563
	4-Jan-2016	Nguyen	C8	DS 207 Rome Road	Routine	Absent	Absent	1.56	7.85	59	0.113	4	<1		536
	4-Jan-2016	Nguyen	C9	DS Airport Vault	Routine	Absent	Absent	0.97	7.75	58	0.102	2	<1		656
	4-Jan-2016	Nguyen	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.45	7.75	59	0.112	2	<1		652
D	11-Jan-2016	West	D1	DS-263 Grant Street	Routine	Absent	Absent	1.01	7.64	62	0.087	3	<1	<0.002	564
	11-Jan-2016	West	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.07	7.33	64	0.100	3	<1	<0.002	773
	11-Jan-2016	West	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.94	7.78	61	0.094	4	<1	0.002	549
	11-Jan-2016	West	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.09	7.87	63	0.101	4	<1	<0.002	558
	11-Jan-2016	West	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.04	7.88	67	0.105	3	<1	0.002	591
	11-Jan-2016	Rodriguez	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.14	7.38	52	0.112	3	<1		541
	11-Jan-2016	Rodriguez	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.13	7.34	55	0.097	3	<1		662
	11-Jan-2016	Rodriguez	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.13	7.36	52	0.106	3	<1		632
	11-Jan-2016	Rodriguez	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.73	7.43	55	0.096	3	<1		634
	11-Jan-2016	Rodriguez	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.21	7.41	60	0.102	4	<1		708
A	19-Jan-2016	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.38	7.87	62	0.108	4	<1	0.004	546
	19-Jan-2016	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	1.41	7.83	61	0.127	3	<1	<0.002	541
	19-Jan-2016	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.86	7.82	67	0.114	3	<1	0.008	597
	19-Jan-2016	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.74	7.92	65	0.084	3	<1	0.002	574
	19-Jan-2016	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.47	7.82	65	0.096	4	<1	0.004	548
	19-Jan-2016	Jackson	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.16	7.82	56	0.105	4	<1		489
	19-Jan-2016	Jackson	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.42	7.88	58	0.295	4	1		583
	19-Jan-2016	Jackson	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.24	7.83	61	0.099	4	1		603
	19-Jan-2016	Jackson	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.46	7.86	60	0.091	4	<1		511
	19-Jan-2016	Jackson	A10	DS 5060 Fitch Middle School	Routine	Present	Absent	1.06	7.88	62	0.109	4	1		624
20-Jan-2016	Kelsey	A10	DS 5060 Fitch Middle School	Repeat	Absent	Absent	1.23								
20-Jan-2016	Kelsey	A10u	DS 4112 General Jim Moore Blvd	Repeat	Absent	Absent	1.18								
20-Jan-2016	Kelsey	A10d	DS Coe Avenue Sun Bay Apt.	Repeat	Absent	Absent	1.19								
B	25-Jan-2016	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.36	7.82	58	0.149	4	<1	<0.002	558
	25-Jan-2016	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.42	7.61	61	0.290	4	<1	<0.002	702
	25-Jan-2016	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.50	7.87	68	0.131	3	<1	<0.002	620
	25-Jan-2016	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.33	7.87	66	0.133	3	<1	0.003	620
	25-Jan-2016	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.46	7.88	75	0.133	4	<1	0.003	676
	25-Jan-2016	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.33	7.51	65	0.143	4	<1		818
	25-Jan-2016	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.54	7.36	66	0.133	4	<1		833
	25-Jan-2016	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.32	7.53	64	1.56	5	1		682
	25-Jan-2016	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.28	7.69	61	0.108	4	<1		624
	25-Jan-2016	Nguyen	B10	DS Seaside High School	Routine	Present	Absent	1.36	7.60	63	0.131	4	<1		706
<b>AVERAGE</b>								<b>1.29</b>	<b>7.73</b>	<b>62</b>	<b>0.157</b>	<b>4</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>613</b>
<b>MAXIMUM</b>								<b>1.86</b>	<b>7.98</b>	<b>75</b>	<b>1.56</b>	<b>5</b>	<b>1</b>	<b>0.008</b>	<b>833</b>
<b>MINIMUM</b>								<b>0.42</b>	<b>7.33</b>	<b>52</b>	<b>0.083</b>	<b>2</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>489</b>

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 FEBRUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
C	1-Feb-2016	Pineda	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.35	7.79	66	0.118	3	<1	<0.002	607
	1-Feb-2016	Pineda	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.42	7.84	70	0.089	2	<1	<0.002	639
	1-Feb-2016	Pineda	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.37	7.89	64	0.093	4	<1	0.002	592
	1-Feb-2016	Pineda	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.29	7.91	62	0.094	4	<1	<0.002	578
	1-Feb-2016	Pineda	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.32	7.93	62	0.103	3	<1	<0.002	584
	1-Feb-2016	Foster	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.09	7.68	58	0.132	4	1		636
	1-Feb-2016	Foster	C7	DS 325 Buna Road	Routine	Absent	Absent	1.21	7.56	59	0.091	4	<1		736
	1-Feb-2016	Foster	C8	DS 207 Rome Road	Routine	Absent	Absent	0.94	7.55	58	0.094	3	<1		707
	1-Feb-2016	Foster	C9	DS Airport Vault	Routine	Absent	Absent	0.88	7.55	53	0.093	2	<1		661
	1-Feb-2016	Foster	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.11	7.51	60	0.092	3	<1		731
D	8-Feb-2016	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	0.96	7.78	62	0.110	3	<1	<0.002	569
	8-Feb-2016	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.47	7.62	64	0.597	3	<1	<0.002	557
	8-Feb-2016	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.92	7.91	61	0.100	4	<1	<0.002	567
	8-Feb-2016	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.03	7.97	62	0.110	4	<1	0.002	570
	8-Feb-2016	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.92	7.93	69	0.108	3	<1	<0.002	622
	8-Feb-2016	Magdalenc	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.11	7.53	58	0.164	3	<1		686
	8-Feb-2016	Magdalenc	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.27	7.71	61	0.149	2	<1		585
	8-Feb-2016	Magdalenc	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.15	7.73	60	0.119	3	1		610
	8-Feb-2016	Magdalenc	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.23	7.80	58	0.146	3	<1		547
	8-Feb-2016	Magdalenc	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.29	7.78	54	0.107	2	<1		534
A	16-Feb-2016	Foster	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.61	7.80	66	0.122	3	<1	<0.002	594
	16-Feb-2016	Foster	A2	DS-3020 King Circle	Routine	Absent	Absent	1.04	7.78	65	0.145	3	<1	<0.002	607
	16-Feb-2016	Foster	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.65	7.87	72	0.106	3	<1	<0.002	634
	16-Feb-2016	Foster	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.78	7.88	68	0.089	3	<1	0.002	610
	16-Feb-2016	Foster	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.21	7.42	66	0.122	4	<1	<0.002	792
	16-Feb-2016	Jackson	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.98	7.34	62	0.250	3	<1		735
	16-Feb-2016	Jackson	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.73	7.45	59	0.133	4	<1		708
	16-Feb-2016	Jackson	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.99	7.55	59	0.136	3	<1		659
	16-Feb-2016	Jackson	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.01	7.44	60	0.141	3	<1		747
	16-Feb-2016	Jackson	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.99	7.74	60	0.155	4	1		664
B	22-Feb-2016	West	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.87	7.89	67	0.071	3	<1	<0.002	584
	22-Feb-2016	West	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.15	7.76	59	0.127	3	<1	<0.002	541
	22-Feb-2016	West	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.03	7.89	73	0.148	3	<1	<0.002	629
	22-Feb-2016	West	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.80	7.94	65	0.165	4	<1	<0.002	571
	22-Feb-2016	West	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.14	7.98	75	0.127	3	<1	<0.002	650
	22-Feb-2016	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.70	7.76	63	0.083	3	<1		534
	22-Feb-2016	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.69	7.81	65	0.131	3	<1		551
	22-Feb-2016	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.27	7.72	64	0.342	3	<1		630
	22-Feb-2016	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.07	7.74	58	0.073	2	<1		636
	22-Feb-2016	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	1.28	7.74	62	0.089	3	<1		594
C	29-Feb-2016	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.67	7.29	66	0.095	3	<1	<0.002	937
	29-Feb-2016	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.54	7.27	67	0.095	2	<1	<0.002	877
	29-Feb-2016	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.51	7.26	66	0.098	3	<1	<0.002	926
	29-Feb-2016	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.75	7.33	66	0.094	3	<1	<0.002	965
	29-Feb-2016	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.79	7.42	66	0.097	3	<1	<0.002	888
	29-Feb-2016	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.18	7.65	61	0.134	2	1		657
	29-Feb-2016	West	C7	DS 325 Buna Road	Routine	Absent	Absent	1.46	7.45	63	0.101	2	<1		734
	29-Feb-2016	West	C8	DS 207 Rome Road	Routine	Absent	Absent	1.27	7.56	61	0.121	4	<1		688
	29-Feb-2016	West	C9	DS Airport Vault	Routine	Absent	Absent	1.09	7.62	58	0.094	4	<1		637
	29-Feb-2016	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.52	7.48	63	0.088	3	<1		730
AVERAGE								1.18	7.68	63	0.130	3	<1	<0.002	661
MAXIMUM								1.79	7.98	75	0.597	4	1	0.002	965
MINIMUM								0.61	7.26	53	0.071	<1	<1	<0.002	534

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 MARCH

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.	
								RESIDUAL	mg/L	pH Units	TEMP	NTU	Color Units	TON	SULFIDE	COND.
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm	
D	7-Mar-2016	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	1.66	7.75	64	0.097	3	<1	<0.002	535	
	7-Mar-2016	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.82	7.64	62	0.093	3	<1	<0.002	544	
	7-Mar-2016	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.29	7.85	61	0.102	3	<1	<0.002	519	
	7-Mar-2016	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.83	7.79	60	0.088	3	<1	<0.002	516	
	7-Mar-2016	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	2.00	7.76	61	0.081	2	<1	<0.002	535	
	7-Mar-2016	Jackson	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.21	7.44	60	0.140	3	<1		699	
	7-Mar-2016	Jackson	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.59	7.67	60	0.116	2	<1		551	
	7-Mar-2016	Jackson	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.50	7.61	63	0.126	3	<1		582	
	7-Mar-2016	Jackson	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.65	7.70	62	0.112	2	<1		616	
	7-Mar-2016	Jackson	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.10	7.74	62	0.123	2	<1		573	
A	14-Mar-2016	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.43	7.80	64	0.091	2	<1	0.003	489	
	14-Mar-2016	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	0.45	8.10	67	0.116	2	<1	0.002	450	
	14-Mar-2016	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.68	7.29	68	0.148	3	<1	<0.002	728	
	14-Mar-2016	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.45	8.12	69	0.064	3	<1	0.003	462	
	14-Mar-2016	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.10	7.36	70	0.133	3	<1	0.003	778	
	14-Mar-2016	Jackson	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.93	7.33	60	0.463	2	<1		658	
	14-Mar-2016	Jackson	A7	DS 3570 3rd Street	Routine	Absent	Absent	1.04	7.58	58	0.189	3	<1		611	
	14-Mar-2016	Jackson	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.21	7.61	60	0.087	3	<1		623	
	14-Mar-2016	Jackson	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.75	7.40	62	0.138	3	<1		694	
	14-Mar-2016	Jackson	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.41	7.68	60	0.148	3	1		613	
B	21-Mar-2016	Kelsey	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.28	8.02	71	0.134	2	<1	<0.002	506	
	21-Mar-2016	Kelsey	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.46	7.74	69	0.252	3	<1	<0.002	602	
	21-Mar-2016	Kelsey	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.21	8.04	70	0.156	3	<1	0.004	505	
	21-Mar-2016	Kelsey	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.36	8.12	72	0.151	3	<1	<0.002	514	
	21-Mar-2016	Kelsey	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.25	8.14	73	0.162	2	<1	0.004	518	
	21-Mar-2016	Foster	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.74	8.11	63	0.115	2	<1		522	
	21-Mar-2016	Foster	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.86	7.71	60	0.284	2	<1		513	
	21-Mar-2016	Foster	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.45	7.67	63	0.314	3	<1		541	
	21-Mar-2016	Foster	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.22	7.64	61	0.158	2	1		645	
	21-Mar-2016	Foster	B10	DS Seaside High School	Routine	Absent	Absent	1.46	7.73	63	0.168	2	<1		567	
C	28-Mar-2016	Pineda	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.72	8.02	70	0.098	2	<1	0.003	512	
	28-Mar-2016	Pineda	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.42	7.53	72	0.093	2	<1	<0.002	758	
	28-Mar-2016	Pineda	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.55	7.78	68	0.085	3	<1	<0.002	554	
	28-Mar-2016	Pineda	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.49	7.86	65	0.102	1	<1	<0.002	506	
	28-Mar-2016	Pineda	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.61	7.90	67	0.109	<1	<1	<0.002	516	
	28-Mar-2016	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.25	7.60	61	0.117	2	1		623	
	28-Mar-2016	West	C7	DS 325 Buna Road	Routine	Absent	Absent	1.28	7.53	61	0.098	2	<1		659	
	28-Mar-2016	West	C8	DS 207 Rome Road	Routine	Absent	Absent	1.18	7.47	63	0.109	2	<1		717	
	28-Mar-2016	West	C9	DS Airport Vault	Routine	Absent	Absent	1.08	7.56	60	0.077	2	<1		621	
	28-Mar-2016	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.58	7.47	65	0.105	2	<1		724	
<b>AVERAGE</b>																
<b>MAXIMUM</b>																
<b>MINIMUM</b>																
								1.31	7.72	64	0.139	2	<1	<0.002	585	
								2.00	8.14	73	0.463	3	1	0.004	778	
								0.43	7.29	58	0.064	<1	<1	<0.002	450	

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 APRIL

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL	pH Units	*F	NTU	Color Units	TON	mg/L	µmho/cm
D	4-Apr-2016	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	0.77	7.82	66	0.121	3	<1	<0.002	606
	4-Apr-2016	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.55	7.74	63	0.141	3	<1	0.002	579
	4-Apr-2016	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.62	7.83	67	0.150	3	<1	0.002	612
	4-Apr-2016	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.60	7.88	65	0.149	3	<1	<0.002	599
	4-Apr-2016	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.42	7.88	68	0.135	3	<1	0.002	621
	4-Apr-2016	Pineda	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.40	7.40	63	0.138	3	<1		642
	4-Apr-2016	Pineda	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.38	7.56	65	0.139	3	<1		590
	4-Apr-2016	Pineda	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.26	7.60	64	0.135	3	<1		569
	4-Apr-2016	Pineda	D9	DS 110 Nijmegen Road	Routine	Present	Absent	1.38	7.60	64	0.143	3	<1		610
	4-Apr-2016	Pineda	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.29	7.64	62	0.119	2	<1		563
	5-Apr-2016	Pineda	D9	DS 110 Nijmegen Road	Repeat	Absent	Absent	1.23							
	5-Apr-2016	Pineda	D9u	DS 201 Nijmegen Road	Repeat	Absent	Absent	1.27							
	5-Apr-2016	Pineda	D9d	DS 108 Nijmegen Road	Repeat	Absent	Absent	1.20							
A	11-Apr-2016	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.95	7.73	59	0.102	2	<1	<0.002	474
	11-Apr-2016	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	1.00	7.95	64	0.111	2	<1	<0.002	453
	11-Apr-2016	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.74	7.17	68	0.115	1	<1	0.005	930
	11-Apr-2016	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.14	7.91	69	0.105	1	<1	<0.002	480
	11-Apr-2016	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.64	7.31	70	0.123	1	<1	<0.002	753
	11-Apr-2016	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.64	7.42	63	0.108	1	1		689
	11-Apr-2016	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.46	7.58	62	0.310	2	<1		673
	11-Apr-2016	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.31	7.55	65	0.134	1	<1		660
	11-Apr-2016	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.26	7.48	67	0.124	<1	<1		749
	11-Apr-2016	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.86	7.60	65	0.896	1	<1		652
B	18-Apr-2016	Pineda	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.04	7.78	71	0.090	2	<1	0.002	553
	18-Apr-2016	Pineda	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.67	7.65	69	0.088	2	<1	<0.002	582
	18-Apr-2016	Pineda	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.50	7.89	71	0.118	3	<1	<0.002	551
	18-Apr-2016	Pineda	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.80	7.99	73	0.116	2	<1	<0.002	505
	18-Apr-2016	Pineda	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.13	7.65	73	0.085	3	<1	<0.002	604
	18-Apr-2016	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.73	7.80	58	0.101	2	<1		479
	18-Apr-2016	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.27	7.75	62	0.120	2	<1		504
	18-Apr-2016	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.71	7.76	60	0.109	3	<1		497
	18-Apr-2016	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.23	7.63	59	0.095	2	1		599
	18-Apr-2016	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	1.55	7.80	66	0.089	3	<1		581
C	25-Apr-2016	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.80	7.30	70	0.134	3	<1	0.005	785
	25-Apr-2016	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.17	7.37	71	0.147	4	<1	0.003	750
	25-Apr-2016	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.85	7.45	70	0.120	4	<1	0.004	697
	25-Apr-2016	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.72	7.61	69	0.140	4	<1	0.004	657
	25-Apr-2016	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.85	7.80	72	0.119	3	<1	0.006	648
	25-Apr-2016	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.22	7.63	54	0.135	4	<1		532
	25-Apr-2016	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	1.22	7.44	53	0.116	4	<1		628
	25-Apr-2016	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	1.31	7.44	58	0.127	3	<1		629
	25-Apr-2016	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.81	7.39	60	0.141	4	<1		657
	25-Apr-2016	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.81	7.43	60	0.132	4	<1		670
<b>AVERAGE</b>								1.11	7.63	65	0.146	3	<1	<0.002	615
<b>MAXIMUM</b>								1.81	7.99	73	0.896	4	1	0.006	930
<b>MINIMUM</b>								0.46	7.17	53	0.085	<1	<1	<0.002	453

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 MAY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.
								RESIDUAL	mg/L					mg/L	SULFIDE
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
D	2-May-2016	Kelsey	D1	DS-263 Grant Street	Routine	Absent	Absent	0.93	8.12	73	0.091	1	<1	0.003	519
	2-May-2016	Kelsey	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.31	7.81	69	0.071	2	<1	0.002	575
	2-May-2016	Kelsey	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.66	7.97	68	0.108	1	<1	0.021	594
	2-May-2016	Kelsey	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.64	7.99	70	0.104	1	<1	0.002	625
	2-May-2016	Kelsey	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.21	7.89	73	0.061	2	<1	0.002	626
	2-May-2016	West	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.53	7.54	63	0.096	3	<1		687
	2-May-2016	West	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.73	7.72	62	0.081	2	<1		544
	2-May-2016	West	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.68	7.75	68	0.161	2	1		573
	2-May-2016	West	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.32	7.71	62	0.079	2	<1		557
	2-May-2016	West	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.46	7.77	65	0.107	2	<1		561
A	9-May-2016	West	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.89	7.79	71	0.107	<1	<1	<0.002	651
	9-May-2016	West	A2	DS-3020 King Circle	Routine	Absent	Absent	0.79	7.79	68	0.099	<1	<1	0.011	595
	9-May-2016	West	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.95	7.44	69	0.136	1	<1	0.004	835
	9-May-2016	West	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.82	7.69	72	0.096	1	<1	<0.002	574
	9-May-2016	West	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.18	7.40	67	0.104	2	<1	0.008	756
	9-May-2016	Kelsey	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.28	7.41	67	0.158	<1	<1		765
	9-May-2016	Kelsey	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.82	7.65	63	0.113	1	<1		689
	9-May-2016	Kelsey	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.21	7.66	54	0.123	1	<1		573
	9-May-2016	Kelsey	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.32	7.49	66	0.101	1	<1		757
	9-May-2016	Kelsey	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.14	7.72	64	0.260	2	<1		712
B	16-May-2016	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.75	7.41	68	0.082	1	<1	<0.002	587
	16-May-2016	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.35	7.52	60	0.057	2	<1	0.002	544
	16-May-2016	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.33	7.70	70	0.072	<1	<1	0.002	617
	16-May-2016	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.89	7.99	65	0.117	1	<1	0.004	464
	16-May-2016	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	2.12	8.08	67	0.055	2	<1	0.003	589
	16-May-2016	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.51	7.89	58	0.061	2	<1		504
	16-May-2016	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.46	7.76	61	0.078	1	<1		522
	16-May-2016	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.54	7.72	55	0.095	1	<1		497
	16-May-2016	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.18	7.62	62	0.073	2	1		630
	16-May-2016	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	1.32	7.62	65	0.104	2	<1		593
C	23-May-2016	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.12	7.88	75	0.067	1	<1	0.002	539
	23-May-2016	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.78	7.58	71	0.081	1	<1	<0.002	715
	23-May-2016	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.99	7.54	72	0.092	1	<1	0.002	776
	23-May-2016	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.79	7.70	67	0.179	1	<1	<0.002	637
	23-May-2016	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.76	7.88	72	0.091	<1	<1	<0.002	633
	23-May-2016	West	C6	DS 314 Ardenes Circle	Routine	Absent	Absent	1.36	7.54	66	0.064	<1	<1		684
	23-May-2016	West	C7	DS 325 Buna Road	Routine	Absent	Absent	1.37	7.45	69	0.097	2	<1		782
	23-May-2016	West	C8	DS 207 Rome Road	Routine	Absent	Absent	1.44	7.45	69	0.080	1	<1		811
	23-May-2016	West	C9	DS Airport Vault	Routine	Absent	Absent	0.91	7.49	70	0.139	2	<1		765
	23-May-2016	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.29	7.46	70	0.086	2	<1		791
D	31-May-2016	Jackson	D1	DS-263 Grant Street	Routine	Absent	Absent	0.74	7.79	74	0.051	3	<1	0.003	652
	31-May-2016	Jackson	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.57	7.62	71	0.053	3	<1	0.003	582
	31-May-2016	Jackson	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.89	7.74	69	0.054	2	<1	0.003	604
	31-May-2016	Jackson	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.03	7.84	68	0.057	2	<1	<0.002	615
	31-May-2016	Jackson	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.71	7.85	73	0.056	1	<1	0.004	654
	31-May-2016	Rosales	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.73	7.69	64	0.087	3	<1		583
	31-May-2016	Rosales	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.93	7.67	65	0.085	1	<1		562
	31-May-2016	Rosales	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.66	7.68	68	0.089	3	<1		575
	31-May-2016	Rosales	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.81	7.70	66	0.108	3	<1		580
	31-May-2016	Rosales	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.94	7.71	63	0.068	2	<1		552
<b>AVERAGE</b>								<b>1.20</b>	<b>7.70</b>	<b>67</b>	<b>0.095</b>	<b>2</b>	<b>&lt;1</b>	<b>0.003</b>	<b>628</b>
<b>MAXIMUM</b>								<b>2.12</b>	<b>8.12</b>	<b>75</b>	<b>0.260</b>	<b>3</b>	<b>1</b>	<b>0.021</b>	<b>835</b>
<b>MINIMUM</b>								<b>0.64</b>	<b>7.40</b>	<b>54</b>	<b>0.051</b>	<b>&lt;1</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>464</b>

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 JUNE

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE**	SPEC. COND. @ 25°C
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
A	6-Jun-2016	Jackson	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.07	7.42	69	0.065	1	<1	0.003	540
	6-Jun-2016	Jackson	A2	DS-3020 King Circle	Routine	Absent	Absent	0.93	7.36	71	0.100	1	<1	0.005	768
	6-Jun-2016	Jackson	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.21	7.25	68	0.165	2	<1	0.003	843
	6-Jun-2016	Jackson	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.26	7.66	70	0.062	2	<1	0.003	580
	6-Jun-2016	Jackson	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.24	7.38	71	0.054	1	<1	0.003	820
	6-Jun-2016	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.21	7.36	69	0.074	2	<1		789
	6-Jun-2016	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.94	7.71	69	0.231	2	<1		722
	6-Jun-2016	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.36	7.59	70	0.078	2	<1		747
	6-Jun-2016	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.29	7.45	71	0.064	2	<1		822
	6-Jun-2016	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.22	7.58	73	0.137	3	<1		835
B	13-Jun-2016	Jackson	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.36	7.80	73	0.052	3	<1	<0.002	638
	13-Jun-2016	Jackson	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.53	7.64	72	0.046	2	<1	0.003	595
	13-Jun-2016	Jackson	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.98	7.85	73	0.085	2	<1	0.002	636
	13-Jun-2016	Jackson	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.71	7.71	74	0.046	1	<1	<0.002	601
	13-Jun-2016	Jackson	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.53	7.66	73	0.077	1	<1	<0.002	588
	13-Jun-2016	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.86	7.79	69	0.071	2	<1		564
	13-Jun-2016	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.50	7.72	69	0.088	<1	1		567
	13-Jun-2016	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.45	7.72	62	0.089	1	<1		514
	13-Jun-2016	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.27	7.63	68	0.055	2	1		664
	13-Jun-2016	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	1.45	7.72	70	0.050	3	<1		595
C	20-Jun-2016	Duplissie	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.01	7.29	73	0.074	2	<1	<0.002	868
	20-Jun-2016	Duplissie	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.35	7.61	70	0.079	2	<1	0.006	692
	20-Jun-2016	Duplissie	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.36	7.73	73	0.068	3	<1	0.003	673
	20-Jun-2016	Duplissie	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.21	7.79	74	0.085	2	<1	0.002	687
	20-Jun-2016	Duplissie	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.38	7.87	74	0.062	2	<1	0.002	674
	20-Jun-2016	Magdalenc	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.27	7.60	66	0.075	2	<1		708
	20-Jun-2016	Magdalenc	C7	DS 325 Buna Road	Routine	Absent	Absent	1.21	7.51	60	0.052	2	<1		741
	20-Jun-2016	Magdalenc	C8	DS 207 Rome Road	Routine	Absent	Absent	1.07	7.46	66	0.053	2	<1		802
	20-Jun-2016	Magdalenc	C9	DS Airport Vault	Routine	Absent	Absent	0.74	7.45	69	0.067	2	1		817
	20-Jun-2016	Magdalenc	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.19	7.45	65	0.091	2	<1		786
D	27-Jun-2016	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	1.25	7.71	64	0.103	1	<1	<0.002	537
	27-Jun-2016	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.26	7.66	63	0.108	2	<1	<0.002	527
	27-Jun-2016	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.76	7.73	68	0.168	2	<1	0.002	571
	27-Jun-2016	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.28	7.77	67	0.083	2	<1	<0.002	557
	27-Jun-2016	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.34	7.71	72	0.050	1	<1	<0.002	595
	27-Jun-2016	Nguyen	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.29	7.56	69	0.103	1	<1		660
	27-Jun-2016	Nguyen	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.24	7.61	69	0.059	1	<1		592
	27-Jun-2016	Nguyen	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.19	7.69	66	0.084	1	<1		574
	27-Jun-2016	Nguyen	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.20	7.65	70	0.060	2	1		613
	27-Jun-2016	Nguyen	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.25	7.68	71	0.071	2	<1		603
<b>AVERAGE</b>								<b>1.28</b>	<b>7.61</b>	<b>69</b>	<b>0.082</b>	<b>2</b>	<b>&lt;1</b>	<b>0.002</b>	<b>668</b>
<b>MAXIMUM</b>								1.86	7.87	74	0.231	3	1	0.006	868
<b>MINIMUM</b>								0.74	7.25	60	0.046	<1	<1	<0.002	514

\*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 JULY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.
								RESIDUAL	mg/L	pH Units	TEMP	°F	NTU	Color Units	TON
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
A	5-Jul-2016	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.74	7.70	64	0.065	3	<1	<0.002	580
	5-Jul-2016	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	0.78	7.74	68	0.076	2	<1	0.005	623
	5-Jul-2016	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.83	7.33	70	0.063	2	<1	<0.002	839
	5-Jul-2016	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.73	7.75	74	0.060	1	<1	0.002	692
	5-Jul-2016	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.41	7.31	71	0.082	2	<1	<0.002	838
	5-Jul-2016	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.35	7.37	71	0.087	<1	<1		841
	5-Jul-2016	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.39	7.64	70	0.137	2	<1		768
	5-Jul-2016	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.08	7.43	67	0.078	2	<1		735
	5-Jul-2016	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.19	7.43	69	0.071	2	<1		822
	5-Jul-2016	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.21	7.78	67	0.124	<1	1		677
B	11-Jul-2016	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.46	7.95	67	0.068	1	<1	<0.002	593
	11-Jul-2016	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.46	7.67	70	0.065	2	<1	<0.002	602
	11-Jul-2016	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.94	7.78	74	0.091	2	<1	<0.002	622
	11-Jul-2016	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.88	7.78	73	0.060	2	<1	<0.002	611
	11-Jul-2016	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.45	7.66	72	0.079	1	<1	<0.002	577
	11-Jul-2016	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.43	7.77	67	0.062	2	<1		554
	11-Jul-2016	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.33	7.66	69	0.151	3	<1		569
	11-Jul-2016	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.86	7.70	68	0.143	2	<1		588
	11-Jul-2016	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.22	7.58	68	0.074	3	1		681
	11-Jul-2016	West	B10	DS Seaside High School	Routine	Absent	Absent	1.16	7.64	69	0.067	2	<1		608
C	18-Jul-2016	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.23	7.74	62	0.125	2	<1	0.002	574
	18-Jul-2016	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.02	7.47	68	0.063	2	<1	<0.002	765
	18-Jul-2016	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.76	7.54	72	0.064	1	<1	<0.002	763
	18-Jul-2016	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.30	7.72	71	0.093	2	<1	<0.002	664
	18-Jul-2016	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.36	7.83	75	0.083	1	<1	<0.002	657
	18-Jul-2016	Rodriguez	C6	DS 314 Ardenes Circle	Routine	Absent	Absent	1.01	7.60	58	0.119	2	1		615
	18-Jul-2016	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	1.09	7.46	63	0.071	1	<1		730
	18-Jul-2016	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	0.97	7.47	61	0.071	2	<1		708
	18-Jul-2016	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.62	7.44	67	0.078	1	<1		778
	18-Jul-2016	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.07	7.46	67	0.085	2	<1		759
D	25-Jul-2016	Foster	D1	DS-263 Grant Street	Routine	Absent	Absent	1.29	7.65	73	0.095	2	<1	0.002	604
	25-Jul-2016	Foster	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.44	7.61	68	0.094	2	<1	0.002	579
	25-Jul-2016	Foster	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.34	7.80	71	0.097	2	<1	0.002	627
	25-Jul-2016	Foster	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.35	7.83	70	0.102	2	<1	0.003	614
	25-Jul-2016	Foster	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.67	7.69	73	0.104	2	<1	0.002	616
	25-Jul-2016	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.07	7.60	70	0.100	1	<1		623
	25-Jul-2016	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.79	7.59	71	0.084	2	<1		594
	25-Jul-2016	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.30	7.62	71	0.102	2	<1		588
	25-Jul-2016	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.39	7.62	66	0.087	2	<1		604
	25-Jul-2016	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.17	7.63	67	0.123	2	<1		560
<b>AVERAGE</b>								<b>0.98</b>	<b>7.63</b>	<b>69</b>	<b>0.089</b>	<b>2</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>661</b>
<b>MAXIMUM</b>								<b>1.83</b>	<b>7.95</b>	<b>75</b>	<b>0.151</b>	<b>3</b>	<b>1</b>	<b>0.005</b>	<b>841</b>
<b>MINIMUM</b>								<b>0.23</b>	<b>7.31</b>	<b>58</b>	<b>0.060</b>	<b>&lt;1</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>554</b>

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 AUGUST

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								RESIDUAL	mg/L						
A	1-Aug-2016	Jackson	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.79	7.50	70	0.077	2	<1	<0.002	784
	1-Aug-2016	Jackson	A2	DS-3020 King Circle	Routine	Absent	Absent	1.56	7.31	69	0.081	1	<1	<0.002	881
	1-Aug-2016	Jackson	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.93	7.26	69	0.077	<1	<1	<0.002	863
	1-Aug-2016	Jackson	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.49	7.29	69	0.078	2	<1	<0.002	909
	1-Aug-2016	Jackson	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.18	7.33	66	0.093	2	<1	<0.002	791
	1-Aug-2016	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.02	7.34	68	0.097	2	<1		782
	1-Aug-2016	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.45	7.67	70	0.217	1	1		762
	1-Aug-2016	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.08	7.46	70	0.100	<1	<1		776
	1-Aug-2016	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.00	7.44	70	0.110	2	<1		849
	1-Aug-2016	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.08	7.73	68	0.223	2	1		698
B	8-Aug-2016	Foster	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.96	7.75	73	0.071	2	<1	<0.002	543
	8-Aug-2016	Foster	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	1.24	7.68	72	0.115	3	<1	<0.002	600
	8-Aug-2016	Foster	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.73	7.76	72	0.107	1	<1	<0.002	549
	8-Aug-2016	Foster	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.55	7.70	73	0.078	2	<1	<0.002	593
	8-Aug-2016	Foster	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.60	7.66	70	0.075	2	<1	<0.002	567
	8-Aug-2016	Magdaleno	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.28	7.67	71	0.126	2	<1		574
	8-Aug-2016	Magdaleno	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.13	7.63	71	0.122	2	<1		589
	8-Aug-2016	Magdaleno	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.23	7.61	70	0.096	3	<1		567
	8-Aug-2016	Magdaleno	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.12	7.55	69	0.102	1	1		681
	8-Aug-2016	Magdaleno	B10	DS Seaside High School	Routine	Absent	Absent	1.32	7.64	69	0.083	1	<1		592
C	15-Aug-2016	West	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.43	7.74	67	0.068	1	<1	<0.002	613
	15-Aug-2016	West	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.79	7.53	70	0.065	2	<1	<0.002	675
	15-Aug-2016	West	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.14	7.45	72	0.064	2	<1	<0.002	842
	15-Aug-2016	West	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.80	7.78	73	0.062	1	<1	<0.002	651
	15-Aug-2016	West	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.67	7.83	74	0.055	2	<1	<0.002	656
	15-Aug-2016	Jackson	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.93	7.48	61	0.078	1	<1		637
	15-Aug-2016	Jackson	C7	DS 325 Buna Road	Routine	Absent	Absent	1.06	7.35	67	0.046	2	<1		800
	15-Aug-2016	Jackson	C8	DS 207 Rome Road	Routine	Absent	Absent	1.13	7.34	64	0.058	1	<1		763
	15-Aug-2016	Jackson	C9	DS Airport Vault	Routine	Absent	Absent	0.77	7.42	53	0.053	1	<1		632
	15-Aug-2016	Jackson	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.07	7.40	62	0.049	2	<1		732
D	22-Aug-2016	Duplissie	D1	DS-263 Grant Street	Routine	Absent	Absent	1.15	7.73	69	0.051	1	<1	<0.002	555
	22-Aug-2016	Duplissie	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.23	7.63	71	0.063	1	<1	<0.002	577
	22-Aug-2016	Duplissie	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.14	7.80	73	0.062	1	<1	0.005	568
	22-Aug-2016	Duplissie	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.47	7.94	72	0.070	1	<1	0.002	505
	22-Aug-2016	Duplissie	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.04	7.67	73	0.066	2	<1	0.010	567
	22-Aug-2016	Rodriguez	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.07	7.69	62	0.052	1	<1		549
	22-Aug-2016	Rodriguez	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.70	7.61	61	0.058	2	3		600
	22-Aug-2016	Rodriguez	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.14	7.65	60	0.051	1	<1		504
	22-Aug-2016	Rodriguez	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.17	7.61	63	0.052	1	<1		543
	22-Aug-2016	Rodriguez	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.14	7.62	66	0.066	1	<1		560
A	29-Aug-2016	Duplissie	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.42	7.66	73	0.073	2	<1	<0.002	651
	29-Aug-2016	Duplissie	A2	DS-3020 King Circle	Routine	Absent	Absent	0.54	7.70	73	0.051	2	<1	0.002	679
	29-Aug-2016	Duplissie	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.70	7.79	78	0.086	2	<1	<0.002	672
	29-Aug-2016	Duplissie	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.63	7.71	74	0.078	2	<1	<0.002	702
	29-Aug-2016	Duplissie	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.10	7.43	67	0.058	1	<1	0.008	744
	29-Aug-2016	Rodriguez	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.05	7.42	62	0.077	2	<1		652
	29-Aug-2016	Rodriguez	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.96	7.51	60	0.090	1	<1		651
	29-Aug-2016	Rodriguez	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.32	7.48	63	0.073	2	<1		669
	29-Aug-2016	Rodriguez	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.67	7.46	65	0.078	1	<1		710
	29-Aug-2016	Rodriguez	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.02	7.53	67	0.091	<1	1		669
AVERAGE								1.02	7.58	68	0.081	2	<1	<0.002	666
MAXIMUM								1.93	7.94	78	0.223	3	3	0.010	909
MINIMUM								0.14	7.26	53	0.046	<1	<1	<0.002	504

\*pH analyzed past 15 minute hold time (all)



**MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017**

**DISTRIBUTION SYSTEM WATER QUALITY**

**REPORTING PERIOD: 2016 SEPTEMBER**

**Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617**

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.
								RESIDUAL	mg/L	pH Units				TEMP	SULFIDE
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
B	6-Sep-2016	Jackson	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.51	7.79	67	0.097	2	<1	<0.002	480
	6-Sep-2016	Jackson	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.89	7.67	64	0.071	2	<1	<0.002	561
	6-Sep-2016	Jackson	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.56	7.90	69	0.055	1	<1	<0.002	496
	6-Sep-2016	Jackson	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.47	7.94	71	0.082	1	<1	<0.002	502
	6-Sep-2016	Jackson	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.18	7.73	72	0.077	2	<1	<0.002	581
	6-Sep-2016	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.15	7.62	71	0.095	2	<1		573
	6-Sep-2016	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.07	7.62	69	0.091	1	<1		581
	6-Sep-2016	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.17	7.65	70	2.87	4	<1		583
	6-Sep-2016	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.03	7.58	70	0.067	2	1		682
	6-Sep-2016	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	1.02	7.62	71	0.064	1	<1		610
C	12-Sep-2016	Foster	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.82	7.64	73	0.051	<1	<1	<0.002	698
	12-Sep-2016	Foster	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.02	7.66	75	0.060	1	<1	0.002	709
	12-Sep-2016	Foster	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.01	7.73	71	0.047	1	<1	<0.002	666
	12-Sep-2016	Foster	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.61	7.69	71	0.047	1	<1	<0.002	641
	12-Sep-2016	Foster	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.79	7.81	71	0.059	1	<1	<0.002	642
	12-Sep-2016	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.00	7.64	69	0.054	1	1.4		680
	12-Sep-2016	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	1.23	7.45	68	0.053	1	<1		749
	12-Sep-2016	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	1.23	7.43	70	0.055	2	<1		769
	12-Sep-2016	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	0.90	7.50	70	0.059	1	1		717
	12-Sep-2016	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.18	7.42	66	0.086	2	<1		726
D	19-Sep-2016	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	0.73	8.03	69	0.164	3	<1	0.002	485
	19-Sep-2016	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.25	7.64	62	0.077	2	<1	<0.002	564
	19-Sep-2016	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.34	7.90	72	0.093	2	<1	<0.002	528
	19-Sep-2016	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.54	7.97	72	0.127	2	<1	0.002	500
	19-Sep-2016	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.78	7.72	69	0.116	2	<1	0.003	557
	19-Sep-2016	West	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.24	7.61	68	0.085	2	<1		584
	19-Sep-2016	West	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.09	7.37	66	0.094	<1	<1		597
	19-Sep-2016	West	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.11	7.64	71	0.093	2	<1		609
	19-Sep-2016	West	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.07	7.70	71	0.077	2	<1		657
	19-Sep-2016	West	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.22	7.82	71	0.123	1	<1		615
A	26-Sep-2016	Nguyen	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.80	7.73	68	0.086	1	<1	0.012	541
	26-Sep-2016	Nguyen	A2	DS-3020 King Circle	Routine	Absent	Absent	0.90	7.84	74	0.064	1	<1	<0.002	506
	26-Sep-2016	Nguyen	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.56	7.27	74	0.093	1	<1	<0.002	809
	26-Sep-2016	Nguyen	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.38	7.74	74	0.134	1	<1	<0.002	589
	26-Sep-2016	Nguyen	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.43	7.36	74	0.084	2	<1	0.002	801
	26-Sep-2016	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.31	7.30	72	0.074	1	<1		786
	26-Sep-2016	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.67	7.48	72	0.205	2	<1		763
	26-Sep-2016	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.18	7.48	72	0.111	2	<1		733
	26-Sep-2016	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.38	7.50	73	0.151	2	<1		786
	26-Sep-2016	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.24	7.60	72	0.077	1	<1		701
<b>AVERAGE</b>															
<b>MAXIMUM</b>								0.98	7.64	70	0.157	2	<1	<0.002	634
<b>MINIMUM</b>								1.56	8.03	75	2.87	4	1.4	0.012	809
								0.34	7.27	62	0.047	<1	<1	<0.002	480

\*pH analyzed past 15 minute hold time (all)

## MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

## DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2016 OCTOBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL** COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL	SPEC.
								RESIDUAL						SULFIDE	COND.
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	@ 25°c µmho/cm
B	3-Oct-2016	Duplissie	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.68	7.81	71	0.109	3	<1	0.006	512
	3-Oct-2016	Duplissie	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	1.10	7.57	67	0.057	2	<1	0.007	596
	3-Oct-2016	Duplissie	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.51	7.68	74	0.099	2	<1	0.009	587
	3-Oct-2016	Duplissie	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.75	7.94	68	0.046	2	<1	0.005	479
	3-Oct-2016	Duplissie	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.02	7.56	73	0.054	2	<1	0.003	611
	3-Oct-2016	Magdalenc	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.01	7.61	66	0.062	2	<1		554
	3-Oct-2016	Magdalenc	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.08	7.56	65	0.086	2	<1		590
	3-Oct-2016	Magdalenc	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.10	7.58	65	0.068	2	<1		564
	3-Oct-2016	Magdalenc	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.22	7.54	64	0.065	1	<1		655
	3-Oct-2016	Magdalenc	B10	DS Seaside High School	Routine	Absent	Absent	0.99	7.63	69	0.051	2	<1		612
C	10-Oct-2016	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.70	7.82	65	0.060	1	<1	<0.002	604
	10-Oct-2016	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.59	7.70	71	0.082	1	<1	<0.002	703
	10-Oct-2016	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.69	7.77	69	0.077	2	<1	0.003	682
	10-Oct-2016	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.80	7.94	71	0.094	2	<1	0.002	543
	10-Oct-2016	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.70	7.92	70	0.073	2	<1	<0.002	635
	10-Oct-2016	Nguyen	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.05	7.61	65	0.084	1	<1		661
	10-Oct-2016	Nguyen	C7	DS 325 Buna Road	Routine	Absent	Absent	1.04	7.48	70	0.071	1	<1		831
	10-Oct-2016	Nguyen	C8	DS 207 Rome Road	Routine	Absent	Absent	0.98	7.35	66	0.101	1	<1		790
	10-Oct-2016	Nguyen	C9	DS Airport Vault	Routine	Absent	Absent	0.87	7.45	66	0.076	2	1		719
	10-Oct-2016	Nguyen	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.07	7.52	70	0.061	2	<1		810
D	17-Oct-2016	West	D1	DS-263 Grant Street	Routine	Absent	Absent	0.42	7.86	71	0.059	<1	<1	<0.002	510
	17-Oct-2016	West	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.90	7.75	69	0.074	<1	<1	<0.002	578
	17-Oct-2016	West	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.52	7.91	70	0.054	1	<1	<0.002	616
	17-Oct-2016	West	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.60	8.01	72	0.080	2	<1	0.006	503
	17-Oct-2016	West	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.87	8.07	75	0.065	<1	<1	<0.002	511
	17-Oct-2016	Nguyen	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.91	7.62	64	0.066	1	<1		565
	17-Oct-2016	Nguyen	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.77	7.62	66	0.065	<1	<1		614
	17-Oct-2016	Nguyen	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.88	7.66	68	0.047	1	<1		580
	17-Oct-2016	Nguyen	D9	DS 110 Nijmegen Road	Routine	Present	Absent	0.97	7.63	66	0.061	1	<1		584
	17-Oct-2016	Nguyen	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.89	7.87	70	0.053	1	<1		594
	18-Oct-2016	Green	D9	DS 110 Nijmegen Road	Repeat	Present	Absent	0.78							
	18-Oct-2016	Green	D9u	DS 201 Nijmegen Road	Repeat	Absent	Absent	0.86							
	18-Oct-2016	Green	D9d	DS 108 Nijmegen Road	Repeat	Absent	Absent	1.03							
	19-Oct-2016	Green	D9	DS 110 Nijmegen Road	Repeat	Absent	Absent	1.01							
	19-Oct-2016	Green	D9u	DS 201 Nijmegen Road	Repeat	Absent	Absent	0.94							
	19-Oct-2016	Green	D9d	DS 108 Nijmegen Road	Repeat	Absent	Absent	0.63							
A	24-Oct-2016	Jackson	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.48	7.58	66	0.064	<1	<1	<0.002	595
	24-Oct-2016	Jackson	A2	DS-3020 King Circle	Routine	Absent	Absent	0.39	7.65	70	0.087	<1	<1	<0.002	632
	24-Oct-2016	Jackson	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.64	7.80	71	0.089	1	<1	<0.002	621
	24-Oct-2016	Jackson	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.57	7.85	71	0.076	2	<1	<0.002	619
	24-Oct-2016	Jackson	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.86	7.40	71	0.057	1	<1	<0.002	756
	24-Oct-2016	Rodriguez	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.78	7.42	59	0.074	1	<1		650
	24-Oct-2016	Rodriguez	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.87	7.41	60	0.050	<1	<1		663
	24-Oct-2016	Rodriguez	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.70	7.44	62	0.059	1	<1		631
	24-Oct-2016	Rodriguez	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.84	7.43	63	0.061	1	<1		694
	24-Oct-2016	Rodriguez	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.81	7.59	66	0.056	1	<1		649
B	31-Oct-2016	Nguyen	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.33	7.93	68	0.080	1	<1	<0.002	521
	31-Oct-2016	Nguyen	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	0.80	7.68	68	0.058	1	<1	<0.002	605
	31-Oct-2016	Nguyen	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.69	7.97	74	0.084	2	<1	<0.002	536
	31-Oct-2016	Nguyen	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.39	7.97	73	0.065	2	<1	<0.002	532
	31-Oct-2016	Nguyen	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.54	7.71	73	0.062	1	<1	<0.002	621
	31-Oct-2016	Magdalenc	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.86	7.74	66	0.065	2	<1		571
	31-Oct-2016	Magdalenc	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.83	7.67	68	0.073	1	<1		625
	31-Oct-2016	Magdalenc	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.79	7.61	64	0.068	1	<1		589
	31-Oct-2016	Magdalenc	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.78	7.61	66	0.067	1	1		670
	31-Oct-2016	Magdalenc	B10	DS Seaside High School	Routine	Absent	Absent	0.85	7.64	68	0.070	1	<1		642
AVERAGE								0.82	7.68	68	0.069	1	<1	0.002	616
MAXIMUM								1.70	8.07	75	0.109	3	1	0.009	831
MINIMUM								0.33	7.35	59	0.046	<1	<1	<0.002	479

\*\*10/18/16 Second Total Coliform for month--No violation

\*pH analyzed past 15 minute hold time (all)

**MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017**

**DISTRIBUTION SYSTEM WATER QUALITY**

**REPORTING PERIOD: 2016 NOVEMBER**

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°c		
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm		
C	7-Nov-2016	Rosales	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.61	7.99	62	0.088	1	<1	<0.002	430		
	7-Nov-2016	Rosales	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.81	7.59	64	0.072	<1	<1	<0.002	611		
	7-Nov-2016	Rosales	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.55	7.65	66	0.110	2	<1	0.002	674		
	7-Nov-2016	Rosales	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.66	7.77	69	0.101	2	<1	0.002	620		
	7-Nov-2016	Rosales	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.55	8.02	70	0.092	1	<1	<0.002	508		
	7-Nov-2016	Foster	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.82	7.56	64	0.107	1	1		641		
	7-Nov-2016	Foster	C7	DS 325 Buna Road	Routine	Absent	Absent	0.94	7.45	67	0.066	1	<1		767		
	7-Nov-2016	Foster	C8	DS 207 Rome Road	Routine	Absent	Absent	1.37	7.38	67	0.103	2	<1		802		
	7-Nov-2016	Foster	C9	DS Airport Vault	Routine	Absent	Absent	0.71	7.49	63	0.074	2	1		669		
	7-Nov-2016	Foster	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.02	7.45	68	0.074	2	<1		767		
D	14-Nov-2016	Kelsey	D1	DS-263 Grant Street	Routine	Absent	Absent	1.12	7.91	74	0.183	1	<1	<0.002	524		
	14-Nov-2016	Kelsey	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.05	7.64	69	0.112	<1	<1	0.002	595		
	14-Nov-2016	Kelsey	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.52	7.89	62	0.057	2	<1	<0.002	529		
	14-Nov-2016	Kelsey	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.66	7.93	67	0.065	1	<1	<0.002	579		
	14-Nov-2016	Kelsey	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.84	8.00	74	0.082	2	<1	<0.002	528		
	14-Nov-2016	Rosales	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.92	7.56	59	0.078	2	<1		608		
	14-Nov-2016	Rosales	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.90	7.72	59	0.051	1	1		536		
	14-Nov-2016	Rosales	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.98	7.80	63	0.041	1	<1		553		
	14-Nov-2016	Rosales	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.96	7.73	58	0.090	1	<1		567		
	14-Nov-2016	Rosales	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.27	7.75	60	0.047	1	<1		550		
A	21-Nov-2016	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.91	7.58	59	0.055	3	<1	<0.002	577		
	21-Nov-2016	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	0.98	7.49	59	0.047	3	<1	<0.002	691		
	21-Nov-2016	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.62	7.33	62	0.051	3	<1	0.004	717		
	21-Nov-2016	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.97	7.50	62	0.043	2	<1	0.002	623		
	21-Nov-2016	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.15	7.42	66	0.054	3	<1	<0.002	740		
	21-Nov-2016	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.24	7.38	65	0.058	1	<1		706		
	21-Nov-2016	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	1.02	7.62	64	0.084	3	<1		674		
	21-Nov-2016	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.20	7.61	63	0.087	3	<1		656		
	21-Nov-2016	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.36	7.60	64	0.056	2	<1		693		
	21-Nov-2016	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.98	7.65	66	0.353	2	<1		688		
B	28-Nov-2016	Foster	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.78	8.04	65	0.121	1	<1	0.002	468		
	28-Nov-2016	Foster	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.79	7.78	66	0.160	1	<1	<0.002	559		
	28-Nov-2016	Foster	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.54	7.83	64	0.152	1	<1	0.005	521		
	28-Nov-2016	Foster	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.86	8.07	71	0.144	1	<1	0.004	497		
	28-Nov-2016	Foster	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.67	7.90	68	0.166	<1	<1	0.003	515		
	28-Nov-2016	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.02	7.75	65	0.114	1	<1		530		
	28-Nov-2016	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.31	7.89	67	0.123	1	<1		546		
	28-Nov-2016	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.13	7.53	65	0.186	2	<1		674		
	28-Nov-2016	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.96	7.61	64	0.122	1	1		656		
	28-Nov-2016	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	0.91	7.66	66	0.155	2	<1		646		
<b>AVERAGE</b>																	
<b>MAXIMUM</b>																	
<b>MINIMUM</b>																	

\*pH analyzed past 15 minute hold time (all)

**MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017**

**DISTRIBUTION SYSTEM WATER QUALITY**

**REPORTING PERIOD: 2016 DECEMBER**

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.
								RESIDUAL	mg/L	pH Units	TEMP	NTU	Color Units	TON	SULFIDE
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
<b>C</b>	5-Dec-2016	West	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.48	7.62	67	0.134	1	<1	<0.002	543
	5-Dec-2016	West	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.69	7.61	63	0.112	1	<1	<0.002	600
	5-Dec-2016	West	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.15	7.71	66	0.124	1	<1	<0.002	744
	5-Dec-2016	West	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.67	7.87	64	0.122	1	<1	0.002	511
	5-Dec-2016	West	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.04	7.74	67	0.108	2	<1	<0.002	770
	5-Dec-2016	Kelsey	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.84	7.65	63	0.142	1	<1		636
	5-Dec-2016	Kelsey	C7	DS 325 Buna Road	Routine	Absent	Absent	1.01	7.81	63	0.103	1	<1		661
	5-Dec-2016	Kelsey	C8	DS 207 Rome Road	Routine	Absent	Absent	1.05	7.72	62	0.074	1	<1		645
	5-Dec-2016	Kelsey	C9	DS Airport Vault	Routine	Absent	Absent	1.04	7.56	60	0.098	2	1		635
	5-Dec-2016	Kelsey	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.99	7.74	65	0.122	2	<1		656
<b>D</b>	12-Dec-2016	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	0.90	7.83	59	0.165	2	<1	<0.002	397
	12-Dec-2016	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.08	7.77	54	0.188	1	<1	<0.002	426
	12-Dec-2016	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.09	7.86	58	0.169	2	<1	<0.002	425
	12-Dec-2016	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.81	7.87	62	0.168	2	<1	<0.002	445
	12-Dec-2016	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.63	8.00	63	0.212	1	<1	<0.002	430
	12-Dec-2016	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.94	7.65	61	0.159	1	<1		573
	12-Dec-2016	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.91	7.70	64	0.144	2	<1		531
	12-Dec-2016	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.08	7.78	64	0.113	2	<1		502
	12-Dec-2016	Duplissie	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.04	7.72	62	0.154	2	<1		548
	12-Dec-2016	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.10	7.78	61	0.171	2	<1		505
<b>A</b>	19-Dec-2016	Kelsey	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.82	7.59	56	0.097	2	<1	<0.002	490
	19-Dec-2016	Kelsey	A2	DS-3020 King Circle	Routine	Absent	Absent	0.62	8.06	64	0.113	2	<1	<0.002	469
	19-Dec-2016	Kelsey	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.29	7.26	64	0.084	2	<1	<0.002	825
	19-Dec-2016	Kelsey	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.62	7.89	68	0.054	1	<1	<0.002	522
	19-Dec-2016	Kelsey	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.85	7.45	64	0.085	2	<1	<0.002	683
	19-Dec-2016	Nguyen	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.98	7.42	64	0.177	1	<1		692
	19-Dec-2016	Nguyen	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.64	7.70	61	0.175	1	<1		625
	19-Dec-2016	Nguyen	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.00	7.63	61	0.121	2	<1		650
	19-Dec-2016	Nguyen	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.03	7.60	61	0.097	1	<1		658
	19-Dec-2016	Nguyen	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.86	7.73	63	0.381	2	1		620
<b>B</b>	27-Dec-2016	Magdaleno	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.74	8.04	60	0.073	1	<1	0.003	454
	27-Dec-2016	Magdaleno	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.94	7.83	61	0.077	1	<1	0.003	532
	27-Dec-2016	Magdaleno	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.71	7.99	65	0.080	1	<1	<0.002	486
	27-Dec-2016	Magdaleno	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.77	8.08	63	0.063	1	<1	<0.002	463
	27-Dec-2016	Magdaleno	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.69	8.07	61	0.070	1	<1	<0.002	458
	27-Dec-2016	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.95	7.30	62	0.065	2	<1		505
	27-Dec-2016	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.94	7.70	61	0.059	1	<1		524
	27-Dec-2016	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.91	7.70	58	0.321	1	<1		543
	27-Dec-2016	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.93	7.68	58	0.068	2	<1		583
	27-Dec-2016	West	B10	DS Seaside High School	Routine	Absent	Absent	0.71	7.69	57	0.132	1	<1		645
<b>AVERAGE</b>								<b>0.86</b>	<b>7.74</b>	<b>62</b>	<b>0.129</b>	<b>1</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>565</b>
<b>MAXIMUM</b>								<b>1.15</b>	<b>8.08</b>	<b>68</b>	<b>0.381</b>	<b>2</b>	<b>1</b>	<b>0.003</b>	<b>825</b>
<b>MINIMUM</b>								<b>0.29</b>	<b>7.26</b>	<b>54</b>	<b>0.054</b>	<b>1</b>	<b>&lt;1</b>	<b>&lt;0.002</b>	<b>397</b>

\*pH analyzed past 15 minute hold time (all)