

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 JANUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP °F	TURBIDITY mg/L	COLOR Color Units	ODOR TON	TOTAL	SPEC. COND. @ 25°C
								RESIDUAL mg/L						SULFIDE mg/L	
C	3-Jan-2017	Magdaleno	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.95	8.00	67	0.069	1	<1	0.002	473
	3-Jan-2017	Magdaleno	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.91	8.02	69	0.083	1	<1	<0.002	492
	3-Jan-2017	Magdaleno	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.83	7.99	61	0.071	1	<1	<0.002	443
	3-Jan-2017	Magdaleno	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.88	7.81	58	0.061	4	<1	<0.002	496
	3-Jan-2017	Magdaleno	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.87	7.88	58	0.047	2	<1	0.005	449
	3-Jan-2017	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.88	7.52	61	0.082	3	<1		588
	3-Jan-2017	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	0.84	7.51	61	0.091	2	<1		639
	3-Jan-2017	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	0.91	7.50	64	0.114	2	<1		638
	3-Jan-2017	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	0.78	7.39	63	0.096	2	1		690
	3-Jan-2017	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.86	7.49	63	0.089	2	<1		606
D	9-Jan-2017	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	1.20	7.92	58	0.047	4	<1	<0.002	438
	9-Jan-2017	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.89	7.65	56	0.107	2	<1	<0.002	494
	9-Jan-2017	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.07	7.79	53	0.070	4	<1	<0.002	424
	9-Jan-2017	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.18	7.96	55	0.093	4	<1	<0.002	417
	9-Jan-2017	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.25	7.84	65	0.062	3	<1	<0.002	506
	9-Jan-2017	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.80	7.55	60	0.089	5	<1		643
	9-Jan-2017	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.83	7.63	56	0.062	1	1		528
	9-Jan-2017	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.75	7.63	64	0.095	1	<1		574
	9-Jan-2017	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.89	7.69	62	0.091	3	<1		562
	9-Jan-2017	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.71	7.68	62	0.074	3	<1		578
A	17-Jan-2017	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.16	7.82	61	0.122	1	<1	0.008	549
	17-Jan-2017	Rodriguez	A2	DS-3020 King Circle**	Routine	Absent	Absent	0.30	7.86	62	4.98	15	<1	0.008	588
	17-Jan-2017	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.27	7.90	62	0.064	1	<1	<0.002	577
	17-Jan-2017	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.17	7.92	62	0.489	4	<1	<0.002	592
	17-Jan-2017	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.61	7.66	63	0.095	1	<1	<0.002	574
	17-Jan-2017	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.63	7.52	61	0.078	2	<1		554
	17-Jan-2017	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.41	7.70	60	0.172	2	<1		569
	17-Jan-2017	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.75	7.62	59	0.088	<1	<1		513
	17-Jan-2017	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.57	7.66	59	0.080	1	<1		536
	17-Jan-2017	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.58	7.78	62	0.694	3	<1		549
B	23-Jan-2017	Foster	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.68	7.84	58	0.051	3	<1	<0.002	532
	23-Jan-2017	Foster	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	0.65	7.64	60	0.152	2	<1	0.004	546
	23-Jan-2017	Foster	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.67	7.96	65	0.077	2	<1	<0.002	601
	23-Jan-2017	Foster	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.62	7.98	67	0.075	2	<1	<0.002	597
	23-Jan-2017	Foster	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.63	7.98	62	0.139	2	<1	<0.002	578
	23-Jan-2017	Magdaleno	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.94	7.61	63	0.076	3	<1		575
	23-Jan-2017	Magdaleno	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.78	7.58	64	0.096	3	<1		581
	23-Jan-2017	Magdaleno	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.79	7.64	58	0.081	3	1		535
	23-Jan-2017	Magdaleno	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.68	7.72	58	0.106	3	<1		564
	23-Jan-2017	Magdaleno	B10	DS Seaside High School	Routine	Absent	Absent	0.54	7.77	54	0.103	3	<1		520
C	30-Jan-2017	Foster	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.96	7.83	66	0.062	2	<1	0.013	486
	30-Jan-2017	Foster	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.05	7.76	67	0.061	2	<1	<0.002	548
	30-Jan-2017	Foster	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.93	7.91	61	0.080	2	<1	0.004	492
	30-Jan-2017	Foster	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.65	7.93	59	0.070	1	<1	<0.002	527
	30-Jan-2017	Foster	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.81	7.97	59	0.065	1	<1	<0.002	487
	30-Jan-2017	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.67	7.85	53	0.096	1	<1		540
	30-Jan-2017	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	0.75	7.76	54	0.060	<1	<1		522
	30-Jan-2017	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	0.73	7.76	53	0.077	1	<1		514
	30-Jan-2017	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.74	7.72	57	0.058	2	1		562
	30-Jan-2017	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.77	7.71	57	0.061	2	<1		536
AVERAGE								0.76	7.76	60	0.202	2	<1	<0.002	542
MAXIMUM								1.25	8.02	69	4.98	15	1	0.013	690
MINIMUM								0.16	7.39	53	0.047	1	<1	<0.002	417

**Turbidity & Color resampled later same day were respectively = 0.358 NTU & = 5 Color Units (and are not included in the monthly average abo *pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 FEBRUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.			
								RESIDUAL	mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm		
D	6-Feb-2017	Nguyen	D1	DS-263 Grant Street	Routine	Absent	Absent	1.16	7.88	65	0.072	2	<1	0.003	583			
	6-Feb-2017	Nguyen	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.13	7.58	61	0.073	1	<1	0.002	554			
	6-Feb-2017	Nguyen	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.02	7.85	59	0.139	1	<1	0.003	548			
	6-Feb-2017	Nguyen	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.98	7.92	56	0.059	<1	<1	<0.002	524			
	6-Feb-2017	Nguyen	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.25	7.94	71	0.051	2	<1	0.003	644			
	6-Feb-2017	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.94	7.78	62	0.088	2	<1		603			
	6-Feb-2017	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.96	7.64	60	0.087	3	<1		590			
	6-Feb-2017	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.96	7.62	64	0.074	2	<1		580			
	6-Feb-2017	Duplissie	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.99	7.62	63	0.088	1	<1		567			
	6-Feb-2017	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.01	7.63	63	0.084	2	<1		582			
A	13-Feb-2017	Duplissie	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.12	7.91	62	0.060	<1	<1	<0.002	573			
	13-Feb-2017	Duplissie	A2	DS-3020 King Circle	Routine	Absent	Absent	1.18	8.05	63	0.047	<1	<1	<0.002	461			
	13-Feb-2017	Duplissie	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.41	7.93	68	0.050	1	<1	<0.002	499			
	13-Feb-2017	Duplissie	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.22	8.01	65	0.052	1	<1	<0.002	480			
	13-Feb-2017	Duplissie	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.03	7.68	64	0.046	<1	<1	<0.002	557			
	13-Feb-2017	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.94	7.71	58	0.075	1	1		534			
	13-Feb-2017	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.74	7.76	57	0.206	1	<1		532			
	13-Feb-2017	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.03	7.74	59	0.063	1	<1		525			
	13-Feb-2017	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.09	7.64	61	0.060	1	<1		544			
	13-Feb-2017	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.80	7.74	61	0.086	1	1		562			
B	21-Feb-2017	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.93	8.14	67	0.077	2	<1	<0.002	487			
	21-Feb-2017	Rosales	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.07	7.69	67	0.079	1	<1	<0.002	593			
	21-Feb-2017	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.14	8.02	69	0.061	<1	<1	<0.002	499			
	21-Feb-2017	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.03	8.10	69	0.051	1	<1	<0.002	492			
	21-Feb-2017	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.84	8.11	69	0.070	2	<1	<0.002	491			
	21-Feb-2017	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.00	7.75	59	0.055	2	<1		521			
	21-Feb-2017	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.00	7.64	60	0.115	1	<1		528			
	21-Feb-2017	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.04	7.68	61	0.070	1	<1		546			
	21-Feb-2017	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.88	7.73	61	0.070	1	<1		558			
	21-Feb-2017	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	0.89	7.82	62	0.094	1	<1		552			
C	27-Feb-2017	Rodriguez	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.89	8.08	58	0.097	2	<1	<0.002	425			
	27-Feb-2017	Rodriguez	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.83	7.85	60	0.089	<1	<1	<0.002	468			
	27-Feb-2017	Rodriguez	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.18	7.82	60	0.084	1	<1	<0.002	502			
	27-Feb-2017	Rodriguez	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.01	7.80	60	0.091	1	<1	<0.002	593			
	27-Feb-2017	Rodriguez	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.10	7.86	66	0.094	2	<1	0.012	555			
	27-Feb-2017	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.91	7.65	63	0.116	2	<1		569			
	27-Feb-2017	West	C7	DS 325 Buna Road	Routine	Absent	Absent	1.18	7.75	63	0.086	1	<1		570			
	27-Feb-2017	West	C8	DS 207 Rome Road	Routine	Absent	Absent	0.91	7.59	65	0.101	1	<1		638			
	27-Feb-2017	West	C9	DS Airport Vault	Routine	Absent	Absent	1.01	7.73	64	0.072	1	<1		581			
	27-Feb-2017	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.99	7.69	63	0.089	2	<1		573			
AVERAGE																		
MAXIMUM																		
MINIMUM																		

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 MARCH

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								RESIDUAL mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
D	6-Mar-2017	Foster	D1	DS-263 Grant Street	Routine	Absent	Absent	1.55	7.85	66	0.078	1	<1	<0.002	638
	6-Mar-2017	Foster	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.23	7.59	66	0.075	1	<1	<0.002	619
	6-Mar-2017	Foster	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.61	7.94	65	0.076	1	<1	<0.002	631
	6-Mar-2017	Foster	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.62	7.97	65	0.088	1	<1	<0.002	625
	6-Mar-2017	Foster	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.53	7.94	69	0.079	1	<1	<0.002	657
	6-Mar-2017	Rodriguez	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.94	7.49	51	0.096	1	<1		510
	6-Mar-2017	Rodriguez	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.96	7.52	52	0.092	1	1		547
	6-Mar-2017	Rodriguez	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.06	7.53	54	0.078	<1	<1		560
	6-Mar-2017	Rodriguez	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.14	7.53	54	0.079	1	<1		539
	6-Mar-2017	Rodriguez	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.21	7.53	59	0.085	1	<1		585
A	13-Mar-2017	Magdalenc	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.21	7.80	64	0.091	2	<1	<0.002	547
	13-Mar-2017	Magdalenc	A2	DS-3020 King Circle	Routine	Absent	Absent	1.23	8.06	58	0.061	2	<1	<0.002	430
	13-Mar-2017	Magdalenc	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.79	7.88	68	0.158	2	<1	<0.002	592
	13-Mar-2017	Magdalenc	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.25	8.06	64	0.088	1	<1	<0.002	465
	13-Mar-2017	Magdalenc	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.11	7.68	62	0.060	1	<1	<0.002	552
	13-Mar-2017	Nguyen	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.10	7.64	65	0.080	2	<1		582
	13-Mar-2017	Nguyen	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.87	7.80	65	0.125	3	<1		592
	13-Mar-2017	Nguyen	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.04	7.71	64	0.062	3	<1		573
	13-Mar-2017	Nguyen	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.12	7.74	64	0.072	2	<1		558
	13-Mar-2017	Nguyen	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.00	7.79	65	0.072	3	<1		588
B	20-Mar-2017	Magdalenc	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.91	7.92	67	0.106	3	<1	<0.002	604
	20-Mar-2017	Magdalenc	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.98	7.67	66	0.090	2	<1	<0.002	617
	20-Mar-2017	Magdalenc	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.12	7.87	71	0.078	3	<1	<0.002	648
	20-Mar-2017	Magdalenc	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.11	7.93	68	0.066	1	<1	<0.002	622
	20-Mar-2017	Magdalenc	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.16	7.93	69	0.076	2	<1	<0.002	648
	20-Mar-2017	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.85	7.54	67	0.075	2	<1		591
	20-Mar-2017	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.95	7.56	67	0.094	2	<1		613
	20-Mar-2017	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.17	7.60	62	0.088	2	<1		586
	20-Mar-2017	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.77	7.60	59	0.091	1	1		555
	20-Mar-2017	West	B10	DS Seaside High School	Routine	Absent	Absent	0.97	7.71	61	0.118	2	<1		606
C	27-Mar-2017	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.08	8.06	68	0.053	2	<1	<0.002	493
	27-Mar-2017	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.84	7.80	70	0.067	1	<1	<0.002	610
	27-Mar-2017	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.89	7.63	68	0.052	2	<1	<0.002	772
	27-Mar-2017	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.72	7.83	65	0.064	3	<1	<0.002	600
	27-Mar-2017	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.78	7.89	67	0.064	1	<1	<0.002	592
	27-Mar-2017	Foster	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.00	7.73	64	0.116	1	<1		610
	27-Mar-2017	Foster	C7	DS 325 Buna Road	Routine	Absent	Absent	0.97	7.76	65	0.087	1	<1		663
	27-Mar-2017	Foster	C8	DS 207 Rome Road	Routine	Absent	Absent	1.12	7.60	64	0.160	3	<1		710
	27-Mar-2017	Foster	C9	DS Airport Vault	Routine	Absent	Absent	0.79	7.70	61	0.076	1	1		567
	27-Mar-2017	Foster	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.04	7.62	66	0.087	2	<1		709
AVERAGE								1.07	7.75	64	0.085	2	<1	<0.002	595
MAXIMUM								1.62	8.06	71	0.160	3	1	<0.002	772
MINIMUM								0.72	7.49	51	0.052	<1	<1	<0.002	430

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 APRIL

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE RESIDUAL	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
D	3-Apr-2017	Rosales	D1	DS-263 Grant Street	Routine	Absent	Absent	0.68	8.01	62	0.098	2	<1	<0.002	478
	3-Apr-2017	Rosales	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.40	7.85	65	0.086	2	<1	0.002	531
	3-Apr-2017	Rosales	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.52	8.01	65	0.094	2	<1	0.002	493
	3-Apr-2017	Rosales	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.37	7.95	68	0.090	<1	<1	<0.002	565
	3-Apr-2017	Rosales	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.37	7.95	67	0.063	1	<1	0.002	603
	3-Apr-2017	Magdalenc	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.91	7.53	64	0.133	2	<1		706
	3-Apr-2017	Magdalenc	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.98	7.76	65	0.095	1	1		553
	3-Apr-2017	Magdalenc	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.65	7.77	67	0.073	2	<1		568
	3-Apr-2017	Magdalenc	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.90	7.75	65	0.114	1	<1		605
	3-Apr-2017	Magdalenc	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.70	7.65	64	0.093	2	<1		553
A	10-Apr-2017	Nguyen	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.89	7.69	67	0.071	2	<1	<0.002	650
	10-Apr-2017	Nguyen	A2	DS-3020 King Circle	Routine	Absent	Absent	1.10	7.71	66	0.052	2	<1	<0.002	748
	10-Apr-2017	Nguyen	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.01	7.70	71	0.080	<1	<1	<0.002	765
	10-Apr-2017	Nguyen	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.03	7.86	67	0.050	1	<1	<0.002	647
	10-Apr-2017	Nguyen	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.15	7.41	66	0.066	2	<1	<0.002	808
	10-Apr-2017	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.13	7.42	65	0.093	3	<1		790
	10-Apr-2017	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.64	7.72	64	0.096	1	<1		618
	10-Apr-2017	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.98	7.60	64	0.064	1	<1		688
	10-Apr-2017	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.89	7.65	65	0.071	1	<1		683
	10-Apr-2017	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.88	7.66	65	0.067	1	<1		687
B	17-Apr-2017	Foster	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.91	7.90	68	0.101	1	<1	<0.002	624
	17-Apr-2017	Foster	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.00	7.80	69	0.071	1	<1	<0.002	615
	17-Apr-2017	Foster	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.05	7.88	71	0.057	2	<1	<0.002	652
	17-Apr-2017	Foster	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.91	7.91	71	0.055	1	<1	0.002	645
	17-Apr-2017	Foster	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.06	7.88	69	0.051	1	<1	0.002	645
	17-Apr-2017	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.78	7.85	66	0.063	2	<1		563
	17-Apr-2017	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.07	7.84	68	0.072	1	<1		585
	17-Apr-2017	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.00	7.77	65	0.185	1	<1		607
	17-Apr-2017	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.87	7.83	59	0.074	2	<1		612
	17-Apr-2017	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	0.91	7.80	61	0.093	2	<1		646
C	24-Apr-2017	Nguyen	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.12	7.93	66	0.067	2	<1	<0.002	584
	24-Apr-2017	Nguyen	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.24	7.89	71	0.068	1	<1	<0.002	659
	24-Apr-2017	Nguyen	C3	DS-3198 Melanie Road	Routine	Absent	Absent	1.25	7.89	71	0.051	2	<1	<0.002	656
	24-Apr-2017	Nguyen	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.89	7.79	70	0.077	1	<1	<0.002	675
	24-Apr-2017	Nguyen	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.13	7.86	72	0.067	1	<1	0.002	661
	24-Apr-2017	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.83	7.66	65	0.068	1	1		657
	24-Apr-2017	West	C7	DS 325 Buna Road	Routine	Absent	Absent	0.96	7.62	65	0.065	1	<1		767
	24-Apr-2017	West	C8	DS 207 Rome Road	Routine	Absent	Absent	0.89	7.54	66	0.061	2	<1		735
	24-Apr-2017	West	C9	DS Airport Vault	Routine	Absent	Absent	1.02	7.54	66	0.084	2	1		729
	24-Apr-2017	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.92	7.53	66	0.055	2	<1		763
AVERAGE								0.92	7.76	66	0.078	1	<1	<0.002	645
MAXIMUM								1.37	8.01	72	0.185	3	1	0.002	808
MINIMUM								0.37	7.41	59	0.050	<1	<1	<0.002	478

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 MAY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.
								RESIDUAL mg/L	pH Units	TEMP °F	NTU	Color Units	TON	SULFIDE mg/L	@ 25°C µmho/cm
D	1-May-2017	Foster	D1	DS-263 Grant Street	Routine	Absent	Absent	1.08	7.98	73	0.193	2	<1	<0.002	522
	1-May-2017	Foster	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.16	7.85	71	0.066	2	<1	<0.002	611
	1-May-2017	Foster	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.74	7.95	71	0.159	1	1	<0.002	635
	1-May-2017	Foster	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.03	7.93	71	0.375	2	<1	0.002	560
	1-May-2017	Foster	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.65	7.88	73	0.648	6	1	0.002	588
	1-May-2017	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.07	7.77	66	0.075	3	1		600
	1-May-2017	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.19	7.78	68	0.090	2	<1		573
	1-May-2017	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.18	7.80	69	0.071	3	<1		584
	1-May-2017	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.30	7.82	64	0.066	2	<1		556
	1-May-2017	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.19	7.79	67	0.050	2	<1		589
A	8-May-2017	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.50	7.38	62	0.051	1	<1	0.002	828
	8-May-2017	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	0.87	7.71	63	0.058	1	1	<0.002	542
	8-May-2017	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.84	7.31	62	0.071	1	<1	<0.002	884
	8-May-2017	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.94	7.57	69	0.046	1	1	<0.002	724
	8-May-2017	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.70	7.80	71	0.070	2	<1	<0.002	829
	8-May-2017	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.12	7.37	66	0.083	2	1		809
	8-May-2017	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.62	7.80	65	0.104	1	<1		700
	8-May-2017	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.05	7.65	66	0.063	2	1		722
	8-May-2017	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.16	7.55	69	0.046	3	<1		816
	8-May-2017	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	1.05	7.83	67	0.070	2	1		735
B	15-May-2017	Rodriguez	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.74	7.71	59	0.084	1	<1	<0.002	443
	15-May-2017	Rodriguez	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.36	7.40	56	0.074	2	<1	<0.002	663
	15-May-2017	Rodriguez	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.04	7.62	68	0.078	1	<1	<0.002	583
	15-May-2017	Rodriguez	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.72	7.98	60	0.086	2	<1	<0.002	440
	15-May-2017	Rodriguez	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.81	7.91	67	0.075	<1	<1	<0.002	489
	15-May-2017	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.34	7.47	68	0.083	1	<1		740
	15-May-2017	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.26	7.51	69	0.114	1	<1		687
	15-May-2017	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.37	7.44	68	0.197	1	1		769
	15-May-2017	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.14	7.62	66	0.079	1	1		693
	15-May-2017	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	1.26	7.51	68	0.081	2	<1		731
C	22-May-2017	Magdaleno	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.84	8.16	70	0.182	1	<1	0.002	499
	22-May-2017	Magdaleno	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.78	8.06	70	0.149	1	<1	<0.002	521
	22-May-2017	Magdaleno	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.88	7.71	67	0.148	2	<1	<0.002	573
	22-May-2017	Magdaleno	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.63	8.05	70	3.13	10	<1	0.006	602
	22-May-2017	Magdaleno	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.87	7.87	66	0.100	1	<1	<0.002	547
	22-May-2017	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.00	7.68	67	0.110	3	1		669
	22-May-2017	West	C7	DS 325 Buna Road	Routine	Absent	Absent	0.73	7.76	67	0.094	3	<1		627
	22-May-2017	West	C8	DS 207 Rome Road	Routine	Absent	Absent	0.97	7.71	68	0.102	2	<1		650
	22-May-2017	West	C9	DS Airport Vault	Routine	Absent	Absent	1.15	7.69	68	0.084	3	<1		659
	22-May-2017	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.69	7.68	68	0.124	2	<1		629
D	30-May-2017	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	0.17	7.67	60	1.97	12	<1	0.004	519
	30-May-2017	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.35	7.65	58	0.086	<1	<1	0.002	511
	30-May-2017	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.59	7.85	63	0.095	2	<1	<0.002	603
	30-May-2017	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.05	7.78	70	0.062	2	<1	<0.002	594
	30-May-2017	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.05	7.65	69	0.078	3	<1	<0.002	588
	30-May-2017	West	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.05	7.58	68	0.163	2	<1		598
	30-May-2017	West	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.12	7.86	68	0.080	1	<1		613
	30-May-2017	West	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.56	7.84	68	0.082	2	<1		597
	30-May-2017	West	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.21	7.84	66	0.079	1	<1		604
	30-May-2017	West	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.15	7.79	67	0.073	2	<1		600
AVERAGE								0.99	7.73	67	0.208	2	<1	<0.002	629
MAXIMUM								1.84	8.16	73	3.13	12	1	0.006	884
MINIMUM								0.05	7.31	56	0.046	<1	<1	<0.002	440

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 JUNE

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								RESIDUAL							
A	5-Jun-2017	Foster	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.71	7.96	65	0.053	4	<1	<0.002	521
	5-Jun-2017	Foster	A2	DS-3020 King Circle	Routine	Absent	Absent	0.84	8.00	73	0.047	3	<1	<0.002	522
	5-Jun-2017	Foster	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.07	8.04	73	0.077	2	<1	<0.002	516
	5-Jun-2017	Foster	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.81	8.00	75	0.053	2	<1	<0.002	538
	5-Jun-2017	Foster	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.16	7.64	72	0.057	3	<1	<0.002	639
	5-Jun-2017	West	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.11	7.53	70	0.105	2	<1		711
	5-Jun-2017	West	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.99	7.65	69	0.067	1	<1		691
	5-Jun-2017	West	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.06	7.66	67	0.114	2	<1		658
	5-Jun-2017	West	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.77	7.83	68	0.133	3	<1		688
	5-Jun-2017	West	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.56	7.63	65	2.37	5	<1		638
B	12-Jun-2017	Pineda	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.86	7.95	73	0.054	1	<1	<0.002	653
	12-Jun-2017	Pineda	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.96	7.78	71	0.057	2	<1	0.002	584
	12-Jun-2017	Pineda	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.99	7.89	76	0.045	2	<1	<0.002	687
	12-Jun-2017	Pineda	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.74	7.93	72	0.047	2	<1	<0.002	639
	12-Jun-2017	Pineda	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.10	7.91	76	0.043	2	<1	<0.002	693
	12-Jun-2017	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.94	7.75	66	0.065	1	<1		532
	12-Jun-2017	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	1.10	7.74	64	0.091	1	<1		504
	12-Jun-2017	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.96	7.72	67	0.063	3	<1		534
	12-Jun-2017	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.83	7.66	67	0.075	2	<1		613
	12-Jun-2017	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	0.93	7.74	70	0.070	2	<1		621
C	19-Jun-2017	Duplissie	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.86	7.99	67	0.051	3	<1	<0.002	471
	19-Jun-2017	Duplissie	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.82	7.96	74	0.063	2	<1	<0.002	527
	19-Jun-2017	Duplissie	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.14	7.46	73	0.057	2	<1	<0.002	690
	19-Jun-2017	Duplissie	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.77	7.67	74	0.092	2	<1	<0.002	750
	19-Jun-2017	Duplissie	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.95	7.59	75	0.066	2	<1	<0.002	710
	19-Jun-2017	Nguyen	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.91	7.62	69	0.056	2	<1		685
	19-Jun-2017	Nguyen	C7	DS 325 Buna Road	Routine	Absent	Absent	1.11	7.63	71	0.067	2	<1		771
	19-Jun-2017	Nguyen	C8	DS 207 Rome Road	Routine	Absent	Absent	1.08	7.63	70	0.070	3	<1		747
	19-Jun-2017	Nguyen	C9	DS Airport Vault	Routine	Absent	Absent	0.84	7.62	71	0.059	2	1		747
	19-Jun-2017	Nguyen	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.15	7.53	73	0.074	3	<1		792
D	26-Jun-2017	Foster	D1	DS-263 Grant Street	Routine	Absent	Absent	0.80	7.94	76	0.057	3	<1	<0.002	534
	26-Jun-2017	Foster	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.03	7.83	72	0.083	2	<1	<0.002	578
	26-Jun-2017	Foster	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.56	7.94	72	0.083	2	<1	<0.002	639
	26-Jun-2017	Foster	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.32	7.93	71	0.072	2	<1	<0.002	545
	26-Jun-2017	Foster	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.50	7.90	74	0.068	3	<1	<0.002	580
	26-Jun-2017	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.92	7.66	69	0.079	4	<1		664
	26-Jun-2017	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.00	7.77	70	0.052	3	<1		594
	26-Jun-2017	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.01	7.75	68	0.071	3	<1		565
	26-Jun-2017	Duplissie	D9	DS 110 Nijmegen Road	Routine	Present	Absent	1.12	7.75	72	0.059	4	<1		590
	26-Jun-2017	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.04	7.84	73	0.059	3	<1		605
	27-Jun-2017	Green	D9	DS 110 Nijmegen Road	Repeat	Absent	Absent	0.98							
	27-Jun-2017	Green	D9u	DS 201 Nijmegen Road	Repeat	Absent	Absent	0.86							
	27-Jun-2017	Green	D9d	DS 108 Nijmegen Road	Repeat	Absent	Absent	0.82							
AVERAGE								0.93	7.78	71	0.126	2	<1	<0.002	624
MAXIMUM								1.32	8.04	76	2	5	1	0.002	792
MINIMUM								0.50	7.46	64	0.043	1	<1	<0.002	471

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 JULY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND. @ 25°C
								RESIDUAL	mg/L						
A	5-Jul-2017	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	1.04	7.79	61	0.101	2	<1	<0.002	492
	5-Jul-2017	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	1.18	8.02	67	0.072	1	<1	0.002	495
	5-Jul-2017	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.79	7.27	66	0.092	1	<1	0.002	938
	5-Jul-2017	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.22	7.81	68	0.077	1	<1	<0.002	537
	5-Jul-2017	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.23	7.48	70	0.114	<1	<1	0.002	731
	5-Jul-2017	Foster	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.03	7.57	68	0.218	2	<1		606
	5-Jul-2017	Foster	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.62	7.76	67	0.116	<1	<1		600
	5-Jul-2017	Foster	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.94	7.73	66	0.088	1	1		616
	5-Jul-2017	Foster	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.41	7.58	69	0.138	3	<1		724
	5-Jul-2017	Foster	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.74	7.84	69	0.103	3	<1		633
B	10-Jul-2017	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.08	7.83	68	0.060	3	<1	<0.002	675
	10-Jul-2017	Rosales	B2	DS-3136 Lynscoot Drive	Routine	Absent	Absent	1.17	7.55	71	0.052	2	<1	<0.002	794
	10-Jul-2017	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.70	7.84	72	0.054	3	<1	<0.002	693
	10-Jul-2017	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.26	7.68	73	0.050	2	<1	<0.002	785
	10-Jul-2017	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.13	7.89	71	0.047	1	<1	0.002	668
	10-Jul-2017	Nguyen	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	1.31	7.41	69	0.057	1	<1		794
	10-Jul-2017	Nguyen	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.97	7.39	68	0.078	3	<1		790
	10-Jul-2017	Nguyen	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.14	7.42	69	0.064	1	1		760
	10-Jul-2017	Nguyen	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.05	7.55	68	0.081	3	1		676
	10-Jul-2017	Nguyen	B10	DS Seaside High School	Routine	Absent	Absent	1.14	7.47	70	0.061	2	<1		776
C	17-Jul-2017	Duplissie	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.32	8.02	70	0.072	5	<1	0.002	489
	17-Jul-2017	Duplissie	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.60	7.83	75	0.084	2	<1	0.002	613
	17-Jul-2017	Duplissie	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.90	7.57	75	0.101	1	<1	<0.002	797
	17-Jul-2017	Duplissie	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.70	7.91	74	0.121	1	<1	0.002	668
	17-Jul-2017	Duplissie	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.61	7.89	76	0.101	2	<1	0.002	644
	17-Jul-2017	Rodriguez	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.94	7.71	63	0.101	1	<1		597
	17-Jul-2017	Rodriguez	C7	DS 325 Buna Road	Routine	Absent	Absent	0.96	7.82	65	0.080	1	<1		559
	17-Jul-2017	Rodriguez	C8	DS 207 Rome Road	Routine	Absent	Absent	0.95	7.76	64	0.085	1	<1		537
	17-Jul-2017	Rodriguez	C9	DS Airport Vault	Routine	Absent	Absent	0.78	7.82	70	0.141	1	1		632
	17-Jul-2017	Rodriguez	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.02	7.78	69	0.097	2	<1		578
D	24-Jul-2017	Magdalenc	D1	DS-263 Grant Street	Routine	Absent	Absent	0.76	7.97	64	0.164	2	<1	0.005	512
	24-Jul-2017	Magdalenc	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.14	7.44	61	0.157	2	<1	0.004	699
	24-Jul-2017	Magdalenc	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.78	7.68	74	2.04	5	<1	0.005	779
	24-Jul-2017	Magdalenc	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.91	7.58	69	0.133	4	<1	0.003	653
	24-Jul-2017	Magdalenc	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.37	7.67	72	0.107	1	<1	0.002	617
	24-Jul-2017	Rodriguez	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.99	7.28	55	0.185	2	<1		657
	24-Jul-2017	Rodriguez	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	1.05	7.35	54	0.169	1	<1		633
	24-Jul-2017	Rodriguez	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	1.05	7.57	64	0.153	5	<1		742
	24-Jul-2017	Rodriguez	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	1.08	7.51	67	0.232	<1	<1		734
	24-Jul-2017	Rodriguez	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.11	7.49	71	0.175	1	<1		799
A	31-Jul-2017	Nguyen	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.46	7.81	74	0.117	3	1	<0.002	663
	31-Jul-2017	Nguyen	A2	DS-3020 King Circle	Routine	Absent	Absent	0.83	7.83	74	0.089	4	<1	0.003	678
	31-Jul-2017	Nguyen	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.78	7.92	75	0.098	3	<1	<0.002	708
	31-Jul-2017	Nguyen	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.64	7.92	72	0.119	4	<1	<0.002	659
	31-Jul-2017	Nguyen	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.07	7.79	72	0.121	4	<1	<0.002	622
	31-Jul-2017	Magdalenc	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.97	7.76	72	0.118	3	<1		624
	31-Jul-2017	Magdalenc	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.65	7.76	71	0.116	2	<1		647
	31-Jul-2017	Magdalenc	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.05	7.71	66	0.108	3	<1		602
	31-Jul-2017	Magdalenc	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.02	7.68	65	0.104	2	<1		543
	31-Jul-2017	Magdalenc	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.94	7.77	66	0.143	2	<1		594
AVERAGE								0.97	7.69	69	0.147	2	<1	<0.002	661
MAXIMUM								1.79	8.02	76	2.04	5	1	0.005	938
MINIMUM								0.32	7.27	54	0.047	<1	<1	<0.002	489

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 AUGUST

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.
								RESIDUAL		TEMP				SULFIDE	@ 25°c
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm
B	7-Aug-2017	Kelsey	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.90	8.07	73	0.127	2	<1	0.003	517
	7-Aug-2017	Kelsey	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.95	7.71	70	0.155	1	<1	0.005	595
	7-Aug-2017	Kelsey	B3	DS-3270 Michael Drive	Routine	Absent	Absent	1.11	7.79	71	0.130	2	<1	0.002	565
	7-Aug-2017	Kelsey	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.83	8.07	74	0.140	1	<1	0.004	521
	7-Aug-2017	Kelsey	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.53	7.74	73	0.101	1	<1	0.004	603
	7-Aug-2017	West	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.66	7.54	73	0.146	2	<1		599
	7-Aug-2017	West	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.54	7.63	72	0.208	2	<1		578
	7-Aug-2017	West	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.88	7.67	69	0.187	2	<1		619
	7-Aug-2017	West	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.99	7.68	68	0.152	3	1		656
	7-Aug-2017	West	B10	DS Seaside High School	Routine	Absent	Absent	1.01	7.69	65	0.103	2	<1		636
C	14-Aug-2017	Foster	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.38	7.58	75	0.128	2	<1	<0.002	675
	14-Aug-2017	Foster	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.77	7.80	76	0.123	2	<1	0.002	699
	14-Aug-2017	Foster	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.75	7.82	73	0.184	2	<1	0.003	678
	14-Aug-2017	Foster	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.33	7.81	70	0.249	2	<1	0.003	621
	14-Aug-2017	Foster	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.35	7.86	67	0.430	3	<1	0.002	627
	14-Aug-2017	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.90	7.73	69	0.167	2	1		657
	14-Aug-2017	West	C7	DS 325 Buna Road	Routine	Absent	Absent	0.71	7.67	71	0.183	2	<1		614
	14-Aug-2017	West	C8	DS 207 Rome Road	Routine	Absent	Absent	1.05	7.66	71	0.121	3	<1		612
	14-Aug-2017	West	C9	DS Airport Vault	Routine	Absent	Absent	0.55	7.65	69	0.117	2	1		649
	14-Aug-2017	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.11	7.65	68	0.110	1	<1		601
D	21-Aug-2017	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	0.92	7.65	64	0.104	2	<1	<0.002	462
	21-Aug-2017	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.03	7.50	63	0.092	2	<1	<0.002	607
	21-Aug-2017	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.06	7.53	68	0.102	1	<1	<0.002	635
	21-Aug-2017	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.98	7.67	71	0.126	2	<1	<0.002	541
	21-Aug-2017	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.92	7.80	75	0.104	2	<1	<0.002	538
	21-Aug-2017	Duplissie	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	1.06	7.51	70	0.108	1	<1		621
	21-Aug-2017	Duplissie	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.99	7.48	71	0.139	<1	<1		662
	21-Aug-2017	Duplissie	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.94	7.44	71	0.091	<1	<1		649
	21-Aug-2017	Duplissie	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.97	7.45	69	0.078	1	<1		643
	21-Aug-2017	Duplissie	D10	DS 180 Okinawa Road	Routine	Absent	Absent	1.09	7.49	71	0.103	1	<1		681
A	28-Aug-2017	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.70	7.60	67	0.094	1	<1	<0.002	589
	28-Aug-2017	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	1.67	7.74	65	0.172	1	<1	<0.002	535
	28-Aug-2017	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.20	8.00	67	0.225	1	<1	<0.002	478
	28-Aug-2017	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.21	7.73	69	0.129	1	<1	<0.002	610
	28-Aug-2017	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.18	7.68	71	0.112	2	<1	<0.002	624
	28-Aug-2017	Rodriguez	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.08	7.53	54	0.150	2	<1		506
	28-Aug-2017	Rodriguez	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.82	7.63	63	0.112	1	<1		582
	28-Aug-2017	Rodriguez	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.03	7.68	60	0.154	1	<1		569
	28-Aug-2017	Rodriguez	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.18	7.63	68	0.108	1	<1		609
	28-Aug-2017	Rodriguez	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.85	7.81	69	0.112	<1	<1		639
AVERAGE								0.93	7.68	69	0.142	2	<1	<0.002	603
MAXIMUM								1.67	8.07	76	0.430	3	1	0.005	699
MINIMUM								0.20	7.44	54	0.078	<1	<1	<0.002	462

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 SEPTEMBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB	TURBIDITY	COLOR	ODOR	TOTAL	SPEC. COND.	
								RESIDUAL	mg/L	pH Units				TEMP	SULFIDE	@ 25°C
								mg/L	pH Units	°F	NTU	Color Units	TON	mg/L	µmho/cm	
B	5-Sep-2017	Nguyen	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.61	7.38	73	0.080	2	<1	<0.002	653	
	5-Sep-2017	Nguyen	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	1.11	7.47	69	0.077	2	<1	<0.002	628	
	5-Sep-2017	Nguyen	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.57	7.35	72	0.093	2	<1	<0.002	651	
	5-Sep-2017	Nguyen	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.69	7.39	73	0.082	1	<1	<0.002	654	
	5-Sep-2017	Nguyen	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.09	7.42	71	0.072	2	<1	<0.002	622	
	5-Sep-2017	Magdalenc	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.93	7.52	71	0.086	1	<1		586	
	5-Sep-2017	Magdalenc	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.80	7.53	71	0.103	3	<1		593	
	5-Sep-2017	Magdalenc	B8	DS 4235 Gigling Road	Routine	Absent	Absent	1.11	7.55	72	0.107	2	<1		592	
	5-Sep-2017	Magdalenc	B9	DS 1830 Cassino Road	Routine	Absent	Absent	1.04	7.75	73	0.091	2	<1		645	
	5-Sep-2017	Magdalenc	B10	DS Seaside High School	Routine	Absent	Absent	1.09	7.55	73	0.092	2	<1		631	
C	11-Sep-2017	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.50	7.32	73	0.099	2	<1	<0.002	885	
	11-Sep-2017	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.76	7.29	73	0.150	<1	<1	<0.002	847	
	11-Sep-2017	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.37	7.35	72	0.093	1	<1	<0.002	821	
	11-Sep-2017	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.91	7.62	75	0.117	1	<1	<0.002	733	
	11-Sep-2017	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.14	7.55	74	0.092	1	<1	<0.002	747	
	11-Sep-2017	West	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	1.09	7.52	73	0.113	<1	1		715	
	11-Sep-2017	West	C7	DS 325 Buna Road	Routine	Absent	Absent	1.16	7.52	75	0.182	1	<1		774	
	11-Sep-2017	West	C8	DS 207 Rome Road	Routine	Absent	Absent	1.03	7.49	74	0.094	1	<1		765	
	11-Sep-2017	West	C9	DS Airport Vault	Routine	Absent	Absent	0.96	7.52	73	0.108	1	1		758	
	11-Sep-2017	West	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	1.26	7.49	75	0.099	1	<1		769	
D	18-Sep-2017	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	0.61	7.78	66	0.140	2	<1	0.003	510	
	18-Sep-2017	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	1.01	7.68	68	0.139	1	<1	0.002	584	
	18-Sep-2017	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.35	7.82	65	0.087	1	<1	<0.002	605	
	18-Sep-2017	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.49	7.86	72	0.167	1	<1	0.002	658	
	18-Sep-2017	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.49	7.72	77	0.164	1	<1	0.002	712	
	18-Sep-2017	Magdalenc	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.94	7.61	70	0.157	<1	<1		651	
	18-Sep-2017	Magdalenc	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.84	7.71	65	0.190	1	<1		584	
	18-Sep-2017	Magdalenc	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.92	7.72	72	0.068	2	<1		627	
	18-Sep-2017	Magdalenc	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.99	7.73	67	0.214	1	<1		589	
	18-Sep-2017	Magdalenc	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.97	7.72	70	0.160	2	<1		616	
A	25-Sep-2017	Rodriguez	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.60	7.85	61	0.081	1	<1	<0.002	484	
	25-Sep-2017	Rodriguez	A2	DS-3020 King Circle	Routine	Absent	Absent	0.82	7.95	65	0.155	1	<1	<0.002	510	
	25-Sep-2017	Rodriguez	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.65	7.90	63	0.075	1	<1	<0.002	603	
	25-Sep-2017	Rodriguez	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.62	7.94	66	0.085	1	<1	<0.002	579	
	25-Sep-2017	Rodriguez	A5	DS-3106 Bayer Street	Routine	Absent	Absent	1.03	7.76	70	0.081	1	<1	<0.002	606	
	25-Sep-2017	Duplissie	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.93	7.82	65	0.095	1	<1		573	
	25-Sep-2017	Duplissie	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.65	7.82	71	0.130	1	<1		631	
	25-Sep-2017	Duplissie	A8	DS 326 Carentan Road	Routine	Absent	Absent	1.06	7.81	71	0.081	2	<1		619	
	25-Sep-2017	Duplissie	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.05	7.82	72	0.140	1	<1		629	
	25-Sep-2017	Duplissie	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.83	7.88	70	0.118	1	1		631	
AVERAGE																
MAXIMUM																
MINIMUM																
								0.88	7.64	71	0.114	1	<1	<0.002	652	
								1.37	7.95	77	0.214	3	1	0.003	885	
								0.35	7.29	61	0.068	<1	<1	<0.002	484	

*pH analyzed past 15 minute hold time (all)

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2017 OCTOBER

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL mg/L	pH Units	*F	NTU	Color Units	TON	mg/L	µmho/cm @ 25°C
B	2-Oct-2017	Rosales	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.44	7.97	56	0.045	1	<1	<0.002	532
	2-Oct-2017	Rosales	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	1.12	7.73	65	0.048	<1	<1	<0.002	612
	2-Oct-2017	Rosales	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.61	7.97	77	0.052	1	<1	0.002	713
	2-Oct-2017	Rosales	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.63	8.05	71	0.059	1	<1	<0.002	578
	2-Oct-2017	Rosales	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.10	7.96	72	0.056	2	<1	<0.002	677
	2-Oct-2017	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.78	7.36	71	0.053	2	<1		655
	2-Oct-2017	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.81	7.44	69	0.062	2	<1		656
	2-Oct-2017	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.78	7.54	69	0.084	3	<1		634
	2-Oct-2017	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.89	7.62	68	0.071	2	1		625
	2-Oct-2017	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	0.79	7.60	68	0.047	2	<1		634
C	9-Oct-2017	Nguyen	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.51	7.91	73	0.068	1	<1	0.004	667
	9-Oct-2017	Nguyen	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	0.57	7.91	69	0.071	2	<1	0.003	635
	9-Oct-2017	Nguyen	C3	DS-3196 Melanie Road	Routine	Absent	Absent	0.62	7.90	74	0.085	1	1	0.006	676
	9-Oct-2017	Nguyen	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.56	7.97	72	0.066	2	<1	0.005	628
	9-Oct-2017	Nguyen	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.58	7.96	72	0.052	4	<1	0.006	635
	9-Oct-2017	Duplissie	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.83	7.77	70	0.053	2	1		619
	9-Oct-2017	Duplissie	C7	DS 325 Buna Road	Routine	Absent	Absent	0.92	7.83	69	0.048	1	<1		596
	9-Oct-2017	Duplissie	C8	DS 207 Rome Road	Routine	Absent	Absent	0.93	7.79	69	0.060	1	<1		604
	9-Oct-2017	Duplissie	C9	DS Airport Vault	Routine	Absent	Absent	0.74	7.78	68	0.059	1	1		590
	9-Oct-2017	Duplissie	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.93	7.82	66	0.051	4	<1		564
D	16-Oct-2017	Rodriguez	D1	DS-263 Grant Street	Routine	Absent	Absent	0.60	7.99	60	0.064	1	<1	<0.002	457
	16-Oct-2017	Rodriguez	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.98	7.52	59	0.058	4	<1	<0.002	559
	16-Oct-2017	Rodriguez	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.39	7.91	58	0.081	4	<1	0.002	472
	16-Oct-2017	Rodriguez	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.51	7.93	66	0.064	2	<1	<0.002	570
	16-Oct-2017	Rodriguez	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.69	7.86	73	0.094	2	<1	<0.002	657
	16-Oct-2017	West	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.99	7.45	70	0.102	2	<1		633
	16-Oct-2017	West	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.90	7.47	67	0.145	2	<1		618
	16-Oct-2017	West	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.92	7.53	67	0.254	5	<1		602
	16-Oct-2017	West	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.70	7.57	65	0.103	2	<1		587
	16-Oct-2017	West	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.86	7.59	68	0.082	2	<1		625
A	23-Oct-2017	Rosales	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.91	7.47	57	0.051	1	<1	<0.002	535
	23-Oct-2017	Rosales	A2	DS-3020 King Circle	Routine	Absent	Absent	1.59	7.49	65	0.045	1	<1	<0.002	582
	23-Oct-2017	Rosales	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	0.34	7.51	67	0.059	2	<1	<0.002	598
	23-Oct-2017	Rosales	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	1.06	7.50	64	0.052	2	<1	<0.002	576
	23-Oct-2017	Rosales	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.98	7.53	68	0.073	2	<1	<0.002	616
	23-Oct-2017	Nguyen	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.02	7.62	64	0.064	2	<1		581
	23-Oct-2017	Nguyen	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.75	7.72	67	0.107	2	<1		611
	23-Oct-2017	Nguyen	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.90	7.71	66	0.064	2	<1		607
	23-Oct-2017	Nguyen	A9	DS 180 Bataan Road	Routine	Absent	Absent	1.18	7.68	67	0.061	2	<1		608
	23-Oct-2017	Nguyen	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.94	7.79	65	0.136	2	<1		597
B	30-Oct-2017	Duplissie	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.54	7.86	69	0.057	2	<1	<0.002	610
	30-Oct-2017	Duplissie	B2	DS-3136 Lynscoth Drive	Routine	Absent	Absent	0.87	7.64	65	0.077	2	<1	<0.002	576
	30-Oct-2017	Duplissie	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.70	7.78	76	0.061	2	<1	<0.002	702
	30-Oct-2017	Duplissie	B4	DS-3100 Everett Circle	Routine	Present	Absent	0.71	7.87	71	0.063	1	<1	<0.002	663
	30-Oct-2017	Duplissie	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.73	7.87	74	0.053	2	<1	0.002	689
	30-Oct-2017	Rodriguez	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.82	7.60	62	0.051	2	<1		562
	30-Oct-2017	Rodriguez	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.98	7.53	62	0.075	2	<1		561
	30-Oct-2017	Rodriguez	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.83	7.57	62	0.058	2	<1		563
	30-Oct-2017	Rodriguez	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.89	7.64	63	0.070	2	1		575
	30-Oct-2017	Rodriguez	B10	DS Seaside High School	Routine	Absent	Absent	0.85	7.64	66	0.059	4	<1		588
	31-Oct-2017	Kelsey	B4	DS-3100 Everett Circle	Repeat	Absent	Absent	0.73							
	31-Oct-2017	Kelsey	B4u	DS-3098 Everett Circle	Repeat	Absent	Absent	0.33							
	31-Oct-2017	Kelsey	B4d	DS-3104 Everett Circle	Repeat	Absent	Absent	0.70							
AVERAGE								0.77	7.71	67	0.071	2	<1	<0.002	606
MAXIMUM								1.59	8.05	77	0.254	5	1	0.006	713
MINIMUM								0.10	7.36	56	0.045	<1	<1	<0.002	457

*pH analyzed past 15 minute hold time (all)