

## SECTION 10 44 16 -FIRE EXTINGUISHERS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes portable fire extinguishers.
- B. Related Sections:
  - 1. Division 10 Section "Fire Extinguisher Cabinets."
  - 2. Division 23 Section "Commercial-Kitchen Hoods" for fire extinguishing systems provided as part of commercial-kitchen exhaust hoods.

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Maintenance Data: Testing requirements and maintenance recommendations from manufacturer to include in maintenance manuals.

#### 1.4 QUALITY ASSURANCE

- A. NFPA Compliance: Fabricate and label fire extinguishers to comply with NFPA 10, "Portable Fire Extinguishers."
- B. Fire Extinguishers: Listed and labeled for type, rating, and classification by an independent testing agency acceptable to authorities having jurisdiction.
  - 1. Provide fire extinguishers approved, listed, and labeled by FMG.

#### 1.5 COORDINATION

- A. Coordinate type and capacity of fire extinguishers with fire protection cabinets to ensure fit and function.

### PART 2 - PRODUCTS

## 2.1 PORTABLE FIRE EXTINGUISHERS

- A. Fire Extinguishers: Type, size, and capacity for each fire protection cabinet indicated.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. J. L. Industries, Inc.; a division of Activar Construction Products Group; Cosmic Extinguishers
    - b. Kidde Residential and Commercial Division; Subsidiary of Kidde plc; Badger ABC Series
    - c. Larsen's Manufacturing Company; MP Series
- B. Multipurpose Dry-Chemical Type: UL-rated 10 lbs. nominal capacity, with monoammonium phosphate-based dry chemical in manufacturer's standard enameled container.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine fire extinguishers for proper charging and tagging.
  - 1. Remove and replace damaged, defective, or undercharged fire extinguishers.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install fire extinguishers in locations indicated and in compliance with requirements of authorities having jurisdiction.

END OF SECTION