

Marina Coast Water District - Recycled Water Distribution Pipelines

Questions and Answers During Re-Bidding - Questions Received through 2020-03-18

Question Number	Question	Answer
1	Page 15076-2 Paragraph C Valve Boxes states "Potable water boxes shall be Christy G05T or equal. Page 15110-4, 2.04 Valve Boxes, C says "boxes are 2-piece fabricated or cast iron. Manufactures listed are Tyler and Neenah Foundry. One valve box is concrete and the other is cast iron. What valve box should be used on this project? Please advise.	Section 15076, 2.01, C takes precedence and matches and Sht T03, MCWD Std. Dtl. W-7, valve boxes.
2	Are 316SS heavy hex bolts and nuts required to be used on exposed pipes and buried pipes per Marina Coast Standard specifications? Or hot-dip galvanized bolts and nuts per project specifications. Please advise.	Bolts and nuts shall conform to Specification Section 15052, 2.04.
3	Mechanical Wedge Action Joint Restraints: According to the project specifications Tandem mechanical wedge action joint restraints are to be used on ductile iron pipe (page 15211-3) and standard mechanical wedge action joint restraints on PVC pipe (page 15244-4). Are Tandem wedge action joint restraints required on ductile iron pipe? Please advise.	An addenda will be issued to address this comment
4	Detail Drawing T03, 1" Air Release & Vac Detail. Item No.1 says Stainless Steel Vented Co (Pipeline VCSP-1530) that enclosure is no longer made. The enclosures that are available are made from Polyethylene or Steel. Please provide an enclosure size, material and finish.	An addenda will be issued to address this comment
5	Drawing T03, Detail W-11A 4" Line Drain Blow-off Assembly: Item No. 13 says 30" minimum valve box. There is no valve box that large. Please provide direction or a new detail.	An addenda will be issued to address this comment
6	Will the bid be rescheduled due to the shelter in place order?	Yes, an addenda will be issued to address this comment.