

DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: 2710017

LABORATORY: Monterey Bay Analytical

ELAP CERTIFICATE: 2385

REPORTING PERIOD: 2021, August

METHOD: SM9223B – Colilert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coil	Chlorine Residual (mg/L)
B	2-August-2021	Kelsey	MCWD	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.84
	2-August-2021	Kelsey	MCWD	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.79
	2-August-2021	Kelsey	MCWD	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.87
	2-August-2021	Kelsey	MCWD	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.06
	2-August-2021	Kelsey	MCWD	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.90
	2-August-2021	Kelsey	MCWD	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.82
	2-August-2021	Kelsey	MCWD	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.98
	2-August-2021	Kelsey	MCWD	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.90
	2-August-2021	Kelsey	MCWD	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.78
	2-August-2021	Kelsey	MCWD	B10	DS Seaside High School	Routine	Absent	Absent	0.79
C	9-August-2021	Kelsey	MCWD	C1	DS-3106 Flower Circle	Routine	Absent	Absent	0.99
	9-August-2021	Kelsey	MCWD	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.03
	9-August-2021	Kelsey	MCWD	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.03
	9-August-2021	Kelsey	MCWD	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	0.90
	9-August-2021	Kelsey	MCWD	C5	DS-3271 Cove Way	Routine	Absent	Absent	0.91
	9-August-2021	Kelsey	MCWD	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.84
	9-August-2021	Kelsey	MCWD	C7	DS 325 Buna Road	Routine	Absent	Absent	0.92
	9-August-2021	Kelsey	MCWD	C8	DS 207 Rome Road	Routine	Absent	Absent	0.99
	9-August-2021	Kelsey	MCWD	C9	DS Airport Vault	Routine	Absent	Absent	0.67
	9-August-2021	Kelsey	MCWD	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.95
D	16-August-2021	Kelsey	MCWD	D1	DS-263 Grant Street	Routine	Absent	Absent	0.84
	16-August-2021	Kelsey	MCWD	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.91
	16-August-2021	Kelsey	MCWD	D3	DS-266 Cosky Drive	Routine	Absent	Absent	0.86
	16-August-2021	Kelsey	MCWD	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	0.83
	16-August-2021	Kelsey	MCWD	D5	DS-3203 DeForest Road	Routine	Absent	Absent	0.83
	16-August-2021	Kelsey	MCWD	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.85
	16-August-2021	Kelsey	MCWD	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.87
	16-August-2021	Kelsey	MCWD	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.84
	16-August-2021	Kelsey	MCWD	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.90
	16-August-2021	Kelsey	MCWD	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.84
A	23-August-2021	Kelsey	MCWD	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.82
	23-August-2021	Kelsey	MCWD	A2	DS-3020 King Circle	Routine	Absent	Absent	0.96
	23-August-2021	Kelsey	MCWD	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.00
	23-August-2021	Kelsey	MCWD	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.87
	23-August-2021	Kelsey	MCWD	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.86
	23-August-2021	Kelsey	MCWD	A6	DS 5871 Imjin Road	Routine	Absent	Absent	1.07
	23-August-2021	Kelsey	MCWD	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.69
	23-August-2021	Kelsey	MCWD	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.88
	23-August-2021	Kelsey	MCWD	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.82
	23-August-2021	Kelsey	MCWD	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.85
B	30-August-2021	Kelsey	MCWD	B1	DS-3076 Clarke Place	Routine	Absent	Absent	0.82
	30-August-2021	Kelsey	MCWD	B2	DS-3136 Lynscott Drive	Routine	Absent	Absent	0.81
	30-August-2021	Kelsey	MCWD	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.87
	30-August-2021	Kelsey	MCWD	B4	DS-3100 Everett Circle	Routine	Absent	Absent	0.89
	30-August-2021	Kelsey	MCWD	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	0.89
	30-August-2021	Kelsey	MCWD	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.84
	30-August-2021	Kelsey	MCWD	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.88
	30-August-2021	Kelsey	MCWD	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.89
	30-August-2021	Kelsey	MCWD	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.81
	30-August-2021	Kelsey	MCWD	B10	DS Seaside High School	Routine	Absent	Absent	0.77

Marina Coast Water District-WS BSSP, Dec. 5, 2006, A ended November 30, 2012. Group sampling is on weekly rotation.

Joe Pineda
Operations & Maintenance Supervisor

9/2/2021
Date of Report