

MARINA COAST WATER DISTRICT - SYSTEM NO. 2710017

DISTRIBUTION SYSTEM WATER QUALITY

REPORTING PERIOD: 2020 JANUARY

Marina Coast Water District Laboratory CDHS-ELAP Laboratory Certificate No. 1617

WEEK NO.	DATE COLLECTED	SAMPLER NAME	BOTTLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	CHLORINE	pH*	LAB TEMP	TURBIDITY	COLOR	ODOR	TOTAL SULFIDE	SPEC. COND.
								RESIDUAL	mg/L	pH Units	°F	NTU	Color Units	TON	mg/L
D	6-Jan-2020	Kelsey	D1	DS-263 Grant Street	Routine	Absent	Absent	1.35	8.12	68	0.089	4	<1	0.003	497
	6-Jan-2020	Kelsey	D2	DS-3020 Jean Street	Routine	Absent	Absent	0.91	7.51	66	0.124	4	<1	<0.002	765
	6-Jan-2020	Kelsey	D3	DS-266 Cosky Drive	Routine	Absent	Absent	1.22	7.93	64	0.104	3	<1	0.003	509
	6-Jan-2020	Kelsey	D4	DS-3180 Ninole Drive	Routine	Absent	Absent	1.23	8.03	64	0.085	4	<1	0.003	471
	6-Jan-2020	Kelsey	D5	DS-3203 DeForest Road	Routine	Absent	Absent	1.29	8.07	64	0.092	4	<1	0.003	491
	6-Jan-2020	Kelsey	D6	DS 1701 Eichelberger Court	Routine	Absent	Absent	0.85	7.56	65	6.58	40	<1		753
	6-Jan-2020	Kelsey	D7	DS 3071 Wittenmyer Court	Routine	Absent	Absent	0.72	7.48	66	0.272	6	<1		750
	6-Jan-2020	Kelsey	D8	DS 11th Street-Imjin Road	Routine	Absent	Absent	0.83	7.47	66	0.136	5	<1		781
	6-Jan-2020	Kelsey	D9	DS 110 Nijmegen Road	Routine	Absent	Absent	0.85	7.54	67	0.135	4	<1		790
	6-Jan-2020	Kelsey	D10	DS 180 Okinawa Road	Routine	Absent	Absent	0.76	7.56	67	0.086	5	<1		775
A	13-Jan-2020	Kelsey	A1	DS-3324 Abdy Way	Routine	Absent	Absent	0.64	7.68	71	0.066	2	<1	0.002	703
	13-Jan-2020	Kelsey	A2	DS-3020 King Circle	Routine	Absent	Absent	0.63	7.63	71	0.059	2	<1	0.002	819
	13-Jan-2020	Kelsey	A3	DS-3166 Crescent Avenue	Routine	Absent	Absent	1.83	7.48	69	0.067	3	<1	0.003	812
	13-Jan-2020	Kelsey	A4	DS-221 Cypress Avenue	Routine	Absent	Absent	0.76	7.60	69	1.06	12	<1	0.003	752
	13-Jan-2020	Kelsey	A5	DS-3106 Bayer Street	Routine	Absent	Absent	0.60	7.48	71	0.095	4	<1	0.002	824
	13-Jan-2020	Kelsey	A6	DS 5871 Imjin Road	Routine	Absent	Absent	0.65	7.50	69	0.134	4	<1		795
	13-Jan-2020	Kelsey	A7	DS 3570 3rd Street	Routine	Absent	Absent	0.54	7.60	68	0.157	3	<1		781
	13-Jan-2020	Kelsey	A8	DS 326 Carentan Road	Routine	Absent	Absent	0.64	7.58	69	0.132	2	<1		797
	13-Jan-2020	Kelsey	A9	DS 180 Bataan Road	Routine	Absent	Absent	0.63	7.51	70	0.124	4	<1		803
	13-Jan-2020	Kelsey	A10	DS 5060 Fitch Middle School	Routine	Absent	Absent	0.59	7.67	71	0.116	4	1		818
B	21-Jan-2020	Kelsey	B1	DS-3076 Clarke Place	Routine	Absent	Absent	1.36	7.73	62	0.069	4	<1	<0.002	482
	21-Jan-2020	Kelsey	B2	DS-3136 Lynscoot Drive	Routine	Absent	Absent	0.63	7.47	61	0.073	3	<1	<0.002	695
	21-Jan-2020	Kelsey	B3	DS-3270 Michael Drive	Routine	Absent	Absent	0.54	7.46	61	0.064	4	<1	0.003	638
	21-Jan-2020	Kelsey	B4	DS-3100 Everett Circle	Routine	Absent	Absent	1.26	8.04	57	0.114	3	<1	<0.002	422
	21-Jan-2020	Kelsey	B5	DS-300 Quebrada del Mar Road	Routine	Absent	Absent	1.20	7.97	61	0.138	3	<1	<0.002	482
	21-Jan-2020	Kelsey	B6	DS 3438 Spotsylvania Court	Routine	Absent	Absent	0.62	7.43	56	0.150	4	<1		652
	21-Jan-2020	Kelsey	B7	DS 6th Avenue 53	Routine	Absent	Absent	0.69	7.46	61	0.153	4	<1		697
	21-Jan-2020	Kelsey	B8	DS 4235 Gigling Road	Routine	Absent	Absent	0.61	7.46	61	0.084	2	<1		692
	21-Jan-2020	Kelsey	B9	DS 1830 Cassino Road	Routine	Absent	Absent	0.64	7.53	59	0.093	5	<1		688
	21-Jan-2020	Kelsey	B10	DS Seaside High School	Routine	Absent	Absent	0.63	7.61	60	0.087	4	<1		713
C	27-Jan-2020	Kelsey	C1	DS-3106 Flower Circle	Routine	Absent	Absent	1.23	7.88	69	0.078	4	<1	<0.002	651
	27-Jan-2020	Kelsey	C2	DS-3073 Zanetta Drive	Routine	Absent	Absent	1.07	7.64	68	0.089	3	<1	0.002	701
	27-Jan-2020	Kelsey	C3	DS-3196 Melanie Road	Routine	Absent	Absent	1.58	7.94	66	0.108	4	<1	0.004	603
	27-Jan-2020	Kelsey	C4	DS-3345 Cardoza Avenue	Routine	Absent	Absent	1.14	7.85	67	0.132	4	<1	<0.002	603
	27-Jan-2020	Kelsey	C5	DS-3271 Cove Way	Routine	Absent	Absent	1.84	7.91	67	0.160	3	<1	0.004	609
	27-Jan-2020	Kelsey	C6	DS 314 Ardennes Circle	Routine	Absent	Absent	0.65	7.65	66	0.087	3	1		746
	27-Jan-2020	Kelsey	C7	DS 325 Buna Road	Routine	Absent	Absent	0.77	7.52	67	0.123	4	<1		751
	27-Jan-2020	Kelsey	C8	DS 207 Rome Road	Routine	Absent	Absent	0.76	7.51	67	0.092	3	<1		742
	27-Jan-2020	Kelsey	C9	DS Airport Vault	Routine	Absent	Absent	0.60	7.52	67	0.076	3	1		758
	27-Jan-2020	Kelsey	C10	DS 4790 Peninsula Point Drive	Routine	Absent	Absent	0.68	7.56	68	0.103	3	<1		749
AVERAGE								0.90	7.65	66	0.295	5	<1	<0.002	689
MAXIMUM								1.84	8.12	71	6.58	40	1	0.004	824
MINIMUM								0.54	7.43	56	0.059	2	<1	<0.002	422

*pH analyzed past 15 minute hold time (all)