

# DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: CA2710017

REPORTING PERIOD: July 2022

LABORATORY: Monterey Bay Analytical

ELAP CERTIFICATE: 2385

METHOD: SM9223B – Colilert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coil	Chlorine Residual
B	05-July-2022	Kelsey	MCWD	B1	DS - 3076 Clarke Place	Routine	Absent	Absent	0.73
	05-July-2022	Kelsey	MCWD	B2	DS - 3136 Lynscott Drive	Routine	Absent	Absent	0.73
	05-July-2022	Kelsey	MCWD	B3	DS - 3270 Michael Drive	Routine	Absent	Absent	0.76
	05-July-2022	Kelsey	MCWD	B4	DS - 3100 Everett Circle	Routine	Absent	Absent	0.82
	05-July-2022	Kelsey	MCWD	B5	DS - 300 Quebrada del Mar Road	Routine	Absent	Absent	1.34
	05-July-2022	Kelsey	MCWD	B6	DS - 3438 Spotsylvania Court	Routine	Absent	Absent	0.79
	05-July-2022	Kelsey	MCWD	B7	DS - 6th Avenue 53	Routine	Absent	Absent	0.74
	05-July-2022	Kelsey	MCWD	B8	DS - 4235 Gigling Road	Routine	Absent	Absent	0.68
	05-July-2022	Kelsey	MCWD	B9	DS - 1830 Cassino Road	Routine	Absent	Absent	0.62
	05-July-2022	Kelsey	MCWD	B10	DS - Seaside High School	Routine	Absent	Absent	0.60
C	11-July-2022	Kelsey	MCWD	C1	DS - 3106 Flower Circle	Routine	Absent	Absent	0.52
	11-July-2022	Kelsey	MCWD	C2	DS - 3073 Zanetta Drive	Routine	Absent	Absent	0.99
	11-July-2022	Kelsey	MCWD	C3	DS - 3196 Melanie Road	Routine	Absent	Absent	0.97
	11-July-2022	Kelsey	MCWD	C4	DS - 3345 Cardoza Avenue	Routine	Absent	Absent	0.66
	11-July-2022	Kelsey	MCWD	C5	DS - 3271 Cove Way	Routine	Absent	Absent	0.80
	11-July-2022	Kelsey	MCWD	C6	DS - 314 Ardennes Circle	Routine	Absent	Absent	0.61
	11-July-2022	Kelsey	MCWD	C7	DS - 325 Buna Road	Routine	Absent	Absent	0.65
	11-July-2022	Kelsey	MCWD	C8	DS - 207 Rome Road	Routine	Absent	Absent	0.83
	11-July-2022	Kelsey	MCWD	C9	DS - Airport Vault	Routine	Absent	Absent	0.52
	11-July-2022	Kelsey	MCWD	C10	DS - 4790 Peninsula Point Drive	Routine	Absent	Absent	0.66
D	18-July-2022	Goncalves	MCWD	D1	DS - 263 Grant Street	Routine	Absent	Absent	0.75
	18-July-2022	Goncalves	MCWD	D2	DS - 3020 Jean Street	Routine	Absent	Absent	0.92
	18-July-2022	Goncalves	MCWD	D3	DS - 266 Cosky Drive	Routine	Absent	Absent	0.90
	18-July-2022	Goncalves	MCWD	D4	DS - 3180 Ninole Drive	Routine	Absent	Absent	0.82
	18-July-2022	Goncalves	MCWD	D5	DS - 3203 DeForest Road	Routine	Absent	Absent	1.25
	18-July-2022	Goncalves	MCWD	D6	DS - 1701 Eichelberger Court	Routine	Absent	Absent	0.84
	18-July-2022	Goncalves	MCWD	D7	DS - 3071 Wittenmyer Court	Routine	Absent	Absent	0.83
	18-July-2022	Goncalves	MCWD	D8	DS - 11th Street-Imjin Road	Routine	Absent	Absent	0.65
	18-July-2022	Goncalves	MCWD	D9	DS - 110 Nijmegen Road	Routine	Absent	Absent	0.83
	18-July-2022	Goncalves	MCWD	D10	DS - 180 Okinawa Road	Routine	Absent	Absent	0.82
A	25-July-2022	Goncalves	MCWD	A1	DS - 3324 Abdy Way	Routine	Absent	Absent	0.93
	25-July-2022	Goncalves	MCWD	A2	DS - 3020 King Circle	Routine	Absent	Absent	0.79
	25-July-2022	Goncalves	MCWD	A3	DS - 3166 Crescent Avenue	Routine	Absent	Absent	0.85
	25-July-2022	Goncalves	MCWD	A4	DS - 221 Cypress Avenue	Routine	Absent	Absent	0.98
	25-July-2022	Goncalves	MCWD	A5	DS - 3106 Bayer Street	Routine	Absent	Absent	0.86
	25-July-2022	Goncalves	MCWD	A6	DS - 5871 Imjin Road	Routine	Absent	Absent	0.88
	25-July-2022	Goncalves	MCWD	A7	DS - 3570 3rd Street	Routine	Absent	Absent	0.61
	25-July-2022	Goncalves	MCWD	A8	DS - 326 Carentan Road	Routine	Absent	Absent	0.75
	25-July-2022	Goncalves	MCWD	A9	DS - 180 Bataan Road	Routine	Absent	Absent	0.87
	25-July-2022	Goncalves	MCWD	A10	DS - 5060 Fitch Middle School	Routine	Absent	Absent	0.68

Marina Coast Water District-WS BSSP, Dec. 5, 2006, Amended November 30, 2012. Amended September 21, 2021. Group sampling is on a weekly rotation.

\_\_\_\_\_  
**Joe Pineda**  
 Operations & Maintenance Supervisor

\_\_\_\_\_  
 August 2, 2022  
 Date of Report