

# DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: CA2710017

REPORTING PERIOD: June 2024

LABORATORY: Monterey Bay Analytical  
 EAP CERTIFICATE: 2386  
 METHOD: SM9223B - Colliert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	Chlorine Residual
B	3-June-2024	Goncalves	MCWD	83	DS - 3076 Clarke Place	Routine	Absent	Absent	0.95
	3-June-2024	Goncalves	MCWD	82	DS - 3136 Lynsott Drive	Routine	Absent	Absent	0.91
	3-June-2024	Goncalves	MCWD	80	DS - 3270 Michael Drive	Routine	Absent	Absent	0.90
	3-June-2024	Goncalves	MCWD	84	DS - 3100 Everett Circle	Routine	Absent	Absent	0.99
	3-June-2024	Goncalves	MCWD	88	DS - 300 Quebrada del Mar Road	Routine	Absent	Absent	0.81
	3-June-2024	Goncalves	MCWD	86	DS - 3438 Spotsylvania Court	Routine	Absent	Absent	0.89
	3-June-2024	Goncalves	MCWD	87	DS - 6th Avenue 53	Routine	Absent	Absent	0.99
	3-June-2024	Goncalves	MCWD	89	DS - 4235 Giggling Road	Routine	Absent	Absent	0.87
	3-June-2024	Goncalves	MCWD	88	DS - 1830 Cassino Road	Routine	Absent	Absent	0.90
	3-June-2024	Goncalves	MCWD	810	DS - Seaside High School	Routine	Absent	Absent	0.88
C	10-June-2024	Goncalves	MCWD	81	DS - 3106 Flower Circle	Routine	Absent	Absent	1.22
	10-June-2024	Goncalves	MCWD	82	DS - 3073 Zanetta Drive	Routine	Absent	Absent	1.08
	10-June-2024	Goncalves	MCWD	83	DS - 3196 Melanie Road	Routine	Absent	Absent	1.14
	10-June-2024	Goncalves	MCWD	84	DS - 3345 Cardoza Avenue	Routine	Absent	Absent	1.12
	10-June-2024	Goncalves	MCWD	85	DS - 3271 Cove Way	Routine	Absent	Absent	1.07
	10-June-2024	Goncalves	MCWD	86	DS - 314 Ardennes Circle	Routine	Absent	Absent	0.91
	10-June-2024	Goncalves	MCWD	87	DS - 325 Buna Road	Routine	Absent	Absent	0.97
	10-June-2024	Goncalves	MCWD	88	DS - 207 Rome Road	Routine	Absent	Absent	1.03
	10-June-2024	Goncalves	MCWD	89	DS - Airport Vault	Routine	Absent	Absent	0.71
	10-June-2024	Goncalves	MCWD	810	DS - 4790 Peninsula Point Drive	Routine	Absent	Absent	0.99
D	17-June-2024	Goncalves	MCWD	D1	DS - 263 Grant Street	Routine	Absent	Absent	1.09
	17-June-2024	Goncalves	MCWD	D2	DS - 3020 Jean Street	Routine	Absent	Absent	1.07
	17-June-2024	Goncalves	MCWD	D3	DS - 266 Cosby Drive	Routine	Absent	Absent	1.10
	17-June-2024	Goncalves	MCWD	D4	DS - 3190 Nirrole Drive	Routine	Absent	Absent	1.06
	17-June-2024	Goncalves	MCWD	D5	DS - 3203 DeForest Road	Routine	Absent	Absent	1.28
	17-June-2024	Goncalves	MCWD	D6	DS - 1701 Eichlberger Court	Routine	Absent	Absent	0.95
	17-June-2024	Goncalves	MCWD	D7	DS - 3071 Wilfannyer Court	Routine	Absent	Absent	0.93
	17-June-2024	Goncalves	MCWD	D8	DS - 11th Street-Injin Road	Routine	Absent	Absent	0.91
	17-June-2024	Goncalves	MCWD	D9	DS - 110 Nijmegen Road	Routine	Absent	Absent	0.94
	17-June-2024	Goncalves	MCWD	D10	DS - 180 Okinawa Road	Routine	Absent	Absent	0.96
A	24-June-2024	Watson	MCWD	A1	DS - 3324 Abby Way	Routine	Absent	Absent	0.98
	24-June-2024	Watson	MCWD	A2	DS - 3020 King Circle	Routine	Absent	Absent	0.90
	24-June-2024	Watson	MCWD	A3	DS - 3166 Crescent Avenue	Routine	Absent	Absent	1.56
	24-June-2024	Watson	MCWD	A4	DS - 221 Cypress Avenue	Routine	Absent	Absent	1.05
	24-June-2024	Watson	MCWD	A5	DS - 3106 Bayer Street	Routine	Absent	Absent	0.96
	24-June-2024	Watson	MCWD	A6	DS - 5871 Injin Road	Routine	Absent	Absent	0.85
	24-June-2024	Watson	MCWD	A7	DS - 3570 3rd Street	Routine	Absent	Absent	0.61
	24-June-2024	Watson	MCWD	A8	DS - 326 Carentan Road	Routine	Absent	Absent	1.07
	24-June-2024	Watson	MCWD	A9	DS - 180 Batatan Road	Routine	Absent	Absent	0.91
	24-June-2024	Watson	MCWD	A10	DS - 5080 Fitch Middle School	Routine	Absent	Absent	0.98

Marina Coast Water District-W/S BSSP, Dec. 5, 2006, Amended November 30, 2012, Amended September 21, 2021. Group sampling is on a weekly rotation.

Joe Pinada  
 Operations & Maintenance Supervisor

Date of Report

24 June 2024