

DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: CA2710017

LABORATORY: Monterey Bay Analytical

ELAP CERTIFICATE: 2385

REPORTING PERIOD: September 2023

METHOD: SM9223B – Colilert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coli	Chlorine Residual
C	5-Sep.-2023	Goncalves	MCWD	C1	DS - 3106 Flower Circle	Routine	Absent	Absent	1.13
	5-Sep.-2023	Goncalves	MCWD	C2	DS - 3073 Zanetta Drive	Routine	Absent	Absent	1.00
	5-Sep.-2023	Goncalves	MCWD	C3	DS - 3196 Melanie Road	Routine	Absent	Absent	0.89
	5-Sep.-2023	Goncalves	MCWD	C4	DS - 3345 Cardoza Avenue	Routine	Absent	Absent	0.91
	5-Sep.-2023	Goncalves	MCWD	C5	DS - 3271 Cove Way	Routine	Absent	Absent	0.96
	5-Sep.-2023	Goncalves	MCWD	C6	DS - 314 Ardennes Circle	Routine	Absent	Absent	0.91
	5-Sep.-2023	Goncalves	MCWD	C7	DS - 325 Buna Road	Routine	Absent	Absent	0.86
	5-Sep.-2023	Goncalves	MCWD	C8	DS - 207 Rome Road	Routine	Absent	Absent	0.90
	5-Sep.-2023	Goncalves	MCWD	C9	DS - Airport Vault	Routine	Absent	Absent	0.50
	5-Sep.-2023	Goncalves	MCWD	C10	DS - 4790 Peninsula Point Drive	Routine	Absent	Absent	0.87
D	11-Sep.-2023	Goncalves	MCWD	D1	DS - 263 Grant Street	Routine	Absent	Absent	0.94
	11-Sep.-2023	Goncalves	MCWD	D2	DS - 3020 Jean Street	Routine	Absent	Absent	0.97
	11-Sep.-2023	Goncalves	MCWD	D3	DS - 266 Cosky Drive	Routine	Absent	Absent	0.90
	11-Sep.-2023	Goncalves	MCWD	D4	DS - 3180 Ninole Drive	Routine	Absent	Absent	0.87
	11-Sep.-2023	Goncalves	MCWD	D5	DS - 3203 DeForest Road	Routine	Absent	Absent	1.13
	11-Sep.-2023	Goncalves	MCWD	D6	DS - 1701 Eichelberger Court	Routine	Absent	Absent	0.96
	11-Sep.-2023	Goncalves	MCWD	D7	DS - 3071 Wittenmyer Court	Routine	Absent	Absent	0.85
	11-Sep.-2023	Goncalves	MCWD	D8	DS - 11th Street-Imjin Road	Routine	Absent	Absent	0.72
	11-Sep.-2023	Goncalves	MCWD	D9	DS - 110 Nijmegen Road	Routine	Absent	Absent	0.89
	11-Sep.-2023	Goncalves	MCWD	D10	DS - 180 Okinawa Road	Routine	Absent	Absent	0.92
A	18-Sep.-2023	Goncalves	MCWD	A1	DS - 3324 Abby Way	Routine	Absent	Absent	0.92
	18-Sep.-2023	Goncalves	MCWD	A2	DS - 3020 King Circle	Routine	Absent	Absent	0.95
	18-Sep.-2023	Goncalves	MCWD	A3	DS - 3166 Crescent Avenue	Routine	Absent	Absent	1.40
	18-Sep.-2023	Goncalves	MCWD	A4	DS - 221 Cypress Avenue	Routine	Absent	Absent	0.97
	18-Sep.-2023	Goncalves	MCWD	A5	DS - 3106 Bayer Street	Routine	Present	Absent	0.90
	18-Sep.-2023	Goncalves	MCWD	A6	DS - 5871 Imjin Road	Routine	Absent	Absent	0.87
	18-Sep.-2023	Goncalves	MCWD	A7	DS - 3570 3rd Street	Routine	Absent	Absent	0.73
	18-Sep.-2023	Goncalves	MCWD	A8	DS - 326 Carentan Road	Routine	Absent	Absent	0.92
	18-Sep.-2023	Goncalves	MCWD	A9	DS - 180 Bataan Road	Routine	Absent	Absent	0.86
	18-Sep.-2023	Goncalves	MCWD	A10	DS - 5060 Fitch Middle School	Routine	Absent	Absent	0.85
	19-Sep.-2023	Goncalves	MCWD	A5	DS - 3106 Bayer Street	Repeat	Absent	Absent	0.97
	19-Sep.-2023	Goncalves	MCWD	A5U	DS - 3106 Bayer Street	Repeat	Absent	Absent	0.87
	19-Sep.-2023	Goncalves	MCWD	A5D	DS - 3106 Bayer Street	Repeat	Absent	Absent	1.14
B	25-Sep.-2023	Goncalves	MCWD	B1	DS - 3076 Clarke Place	Routine	Absent	Absent	1.10
	25-Sep.-2023	Goncalves	MCWD	B2	DS - 3136 Lynscott Drive	Routine	Absent	Absent	1.16
	25-Sep.-2023	Goncalves	MCWD	B3	DS - 3270 Michael Drive	Routine	Absent	Absent	0.90
	25-Sep.-2023	Goncalves	MCWD	B4	DS - 3100 Everett Circle	Routine	Absent	Absent	1.08
	25-Sep.-2023	Goncalves	MCWD	B5	DS - 300 Quebrada del Mar Road	Routine	Absent	Absent	0.88
	25-Sep.-2023	Goncalves	MCWD	B6	DS - 3438 Spotsylvania Court	Routine	Absent	Absent	0.82
	25-Sep.-2023	Goncalves	MCWD	B7	DS - 6th Avenue 53	Routine	Absent	Absent	0.85
	25-Sep.-2023	Goncalves	MCWD	B8	DS - 4235 Gigling Road	Routine	Absent	Absent	1.13
	25-Sep.-2023	Goncalves	MCWD	B9	DS - 1830 Cassino Road	Routine	Absent	Absent	1.00
	25-Sep.-2023	Goncalves	MCWD	B10	DS - Seaside High School	Routine	Absent	Absent	0.89

Marina Coast Water District-WS BSSP, Dec. 5, 2006, Amended November 30, 2012. Amended September 21, 2021. Group sampling is on a weekly rotation.

October 5, 2023

Joe Pineda, Operations & Maintenance Supervisor

Date of Report